

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 12-Dec-11 TO 18-Dec-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Cent_Sect	TARAPUR-4	540	6-Nov-11	01:00		Continued.	Annual Overhaul
Parli	Unit 3	210	12-Nov-11	21:25		Continued.	Annual Overhaul.
CPP	JSW (J) U2	300	10-Dec-11	23:30		Continued.	Annual Shutdown
Koyna	ST-IV 2	250	18-Dec-11	10:00		Continued.	Preventive Maint. work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 4	500	17-Oct-11	03:55		Continued.	Hand Tripped
CPP	WPCL U-4	135	2-Nov-11	04:40		Continued.	ID Fan Problem, Preparation for P.G. Test.
Dabhol	1A	230	14-Nov-11	12:00	13-Dec-11	12:02	Gas Shortage.
Chandrapur	Unit 5	500	10-Dec-11	12:44	13-Dec-11	14:02	Boiler Tube Leakage.
Chandrapur	Unit 6	500	11-Dec-11	06:20	14-Dec-11	20:59	Boiler Tube Leakage.
Khaparkhedda	Unit 5	500	12-Dec-11	08:34	12-Dec-11	12:07	Drum level high.
Dabhol	3B	230	12-Dec-11	23:46		Continued.	Gas shortage.
Dabhol	1A	230	13-Dec-11	21:33	14-Dec-11	00:20	To attend Tie Breaker Lockout of Dabhol-N.Koyna-I at Dabhol end
Dabhol	3A	230	13-Dec-11	16:09		Continued.	Gas Shortage
Dabhol	3X	290	13-Dec-11	16:09		Continued.	Gas Shortage
Cent_Sect	NTPC(V) 9	500	14-Dec-11	00:11	16-Dec-11	03:18	Boiler Tube Leakage
Koyna	ST - IV 4	250	14-Dec-11	23:00	16-Dec-11	11:00	Generator Air Cooler Leakage and T/F Oil Leakage
Koyna	Unit 9	80	15-Dec-11	00:00	16-Dec-11	19:05	Generator Stop Guide Bearing Temp.Meter replacement
Koyna	ST-IV 2	250	15-Dec-11	08:30	15-Dec-11	11:00	Preventive Maintenance.
Koyna	Unit 7	80	15-Dec-11	12:05	15-Dec-11	15:10	Oil Leakage.
Tata	Trombay 6	500	15-Dec-11	20:54	15-Dec-11	23:48	Drum Level Low.
Bhusawal	Unit 3	210	16-Dec-11	04:35	16-Dec-11	06:46	Furnace Pressure High.
Bhusawal	Unit 2	210	16-Dec-11	12:13		Continued.	BLR T/L.
Cent_Sect	NTPC (K-2)	210	16-Dec-11	12:42	16-Dec-11	15:22	W/Dn.
CPP	JSW (J) U3	300	16-Dec-11	18:24	17-Dec-11	07:57	Electrical fault.
Parli	Unit 7	250	16-Dec-11	23:08		Continued.	W/Dn due to CHP Problem.
Koradi	Unit 5	200	17-Dec-11	04:02	17-Dec-11	14:25	Flame/Failure
Uran	Unit 5	108	17-Dec-11	11:10	17-Dec-11	17:19	Filter Replacement Work.
CPP	JSW (J) U3	300	17-Dec-11	12:53	18-Dec-11	03:18	Generator Protection Tripped.
Koradi	Unit 6	210	17-Dec-11	13:17	17-Dec-11	20:13	Turbine Problem.
Cent_Sect	NTPC(K-6)	500	17-Dec-11	13:17	17-Dec-11	20:13	Turbine Problem.
Koyna	UNIT 6	75	17-Dec-11	23:15	18-Dec-11	04:35	Leakage in generator air cooler.
Koradi	Unit 5	200	18-Dec-11	02:24		Continued.	Coal mill problem.