

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	3 Jan		4 Jan		5 Jan		6 Jan		7 Jan		8 Jan		9 Jan	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	420.2	407	419	409.4	423.8	407.6	419.6	410	419.6	408.2	420.2	411.2	421.4	411.2
KORDY	422.4	405.6	424.4	408.8	426.8	411.2	422.8	406	422.4	409.2	420	408.4	423.2	406.4
PARLY2	422.6	398	422	398.6	421.4	399.8	418.4	396.2	416.6	392.6	417.8	396.2	419	398.6
BHSQL2	431	400.4	427.4	400.4	430.4	401.6	429.2	396.8	429.2	405.2	429.8	407	433.4	402.8
DHULE	425.7	398	429.7	400	429.7	403.9	427.7	403.9	425.7	403.9	425.7	403.9	429.7	401.9
PADGE	426	407.3	424.8	408.5	422.3	407.3	423.6	410.2	424.4	408.3	422.7	408.9	422.3	408.1
KARAD2	428	403.4	425.6	402.2	424.4	401.6	426.2	401.6	423.2	400.4	424.4	401.8	423.2	401.5