

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	4 Apr		5 Apr		6 Apr		7 Apr		8 Apr		9 Apr		10 Apr	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	416.6	404.6	416.6	405.8	418.4	408.2	419	402.2	419	409.4	417.2	406.4	419	408.2
KORDY	420.4	408.4	421.2	410	420	410.4	422	413.6	422.4	414	419.2	411.6	419.6	411.2
PARLY2	411.8	393.2	413	393.2	416	393.2	412.4	389	413	385.4	411.2	387.2	416	387.8
BHSQL2	426.8	404	425.6	408.2	429.8	408.2	429.8	409.4	426.2	414.2	427.4	410	426.2	407.6
DHULE	427.7	400	425.7	409.9	427.7	407.9	427.7	407.9	427.7	413.8	425.7	400	425.7	400
PADGE	420.3	406	419.7	400	417	402.8	418.3	405.2	421.6	404.9	419.1	403.8	421.5	405.3
KARAD2	425	402.2	422	397.4	422.6	357.2	419.6	398	420.2	396.8	421.4	393.8	426.8	385.4