

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	4 July		5 July		6 July		7 July		8 July		9 July		10 July	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	421.4	414.2	423.8	413	423.2	407.6	423.8	411.2	423.2	414.8	424.4	414.8	422.6	415.4
KORDY	419.2	410.4	420.4	410.4	421.2	410.4	423.2	377.6	427.2	416.8	427.6	417.2	425.6	416.4
PARLY2	417.2	399.8	419	400.4	419	396.8	425	399.2	424.4	405.8	426.8	404	423.2	405.2
BHSQL2	429.8	411.2	428.6	408.8	433.4	407	434	413.6	436.4	420.8	438.2	418.4	434	417.2
DHULE	429.7	405.9	427.7	405.9	427.7	401.9	431.6	411.8	431.6	411.8	433.6	415.8	433.6	413.8
PADGE	421.8	407.1	421.8	401.7	421.9	402.8	420.6	406.7	420.1	408.2	425.2	407	423.4	406
KARAD2	427.4	411.2	425	405.2	425.6	405.2	428.6	407.6	428.6	413	431	408.2	428.6	411.2