

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**

**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

| Date   | 2 Aug |       | 3 Aug |       | 4 Aug |       | 5 Aug |       | 6 Aug |       | 7 Aug |       | 8 Aug |       |
|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|        | Max   | Min   | Max   | Min   | Max   | Min   | Max   | Min   | Max   | Min   | Max   | Min   | Max   | Min   |
| CHDPR  | 418.4 | 405.8 | 418.4 | 407.6 | 414.8 | 404.6 | 419.0 | 403.4 | 416.0 | 403.4 | 419.0 | 404.0 | 419.6 | 406.4 |
| KORDY  | 420.8 | 406.4 | 420.4 | 412.0 | 421.2 | 411.6 | 416.4 | 408.0 | 418.0 | 411.6 | 422.4 | 408.8 | 422.8 | 410.0 |
| PARLY2 | 423.2 | 398.0 | 421.4 | 405.2 | 420.2 | 404.0 | 422.0 | 394.4 | 423.8 | 400.4 | 425.6 | 398.0 | 423.8 | 399.8 |
| BHSQL2 | 435.2 | 411.8 | 433.4 | 414.8 | 434.0 | 414.2 | 431.6 | 410.6 | 432.2 | 414.8 | 436.4 | 413.6 | 437.6 | 418.4 |
| DHULE  | 435.6 | 405.9 | 435.6 | 411.8 | 435.6 | 411.8 | 431.6 | 407.9 | 433.6 | 409.9 | 433.6 | 407.9 | 433.6 | 411.8 |
| PADGE  | 427.6 | 409.0 | 426.8 | 405.7 | 424.8 | 407.1 | 422.7 | 403.2 | 422.3 | 407.3 | 423.0 | 399.6 | 422.7 | 407.4 |
| KARAD2 | 432.8 | 413.6 | 430.2 | 408.6 | 428.4 | 409.3 | 429.8 | 407.2 | 432.8 | 406.4 | 430.4 | 406.4 | 432.8 | 408.8 |