

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	5 Sep		6 Sep		7 Sep		8 Sep		9 Sep		10 Sep		11 Sep	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	426.2	411.8	425	414.8	423.8	407	425.6	405.8	425.6	405.8	425.6	413.6	425	414.2
KORDY	425.2	408.4	424.4	412	426	404	427.2	401.6	423.6	408	424.4	413.6	426	414.8
PARLY2	425.6	403.4	423.2	408.2	423.8	404	423.2	402.8	424.4	398	423.8	400.4	425	405.2
BHSQL2	433.4	408.2	434	415.4	431.6	407	432.8	404	431	404.6	433.4	407	435.2	412.4
DHULE	431.6	409.9	429.7	415.8	431.6	407.9	431.6	403.9	429.7	407.9	429.7	407.9	431.6	411.8
PADGE	424.9	402.3	426.5	406.6	424.5	402	423.4	398.4	421.6	407.1	421.5	402.9	423.9	411.6
KARAD2	432.8	413.6	434	413.6	434	414.8	432.8	395	433.4	414.2	430.4	410.6	433.4	413