

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.

MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	4 Oct		5 Oct		6 Oct		7 Oct		8 Oct		9 Oct		10 Oct	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	419.6	408.2	422.6	409.4	420.2	407.6	419.0	410.6	419.0	406.4	417.2	405.8	415.4	404.6
KORDY	416.4	404.4	421.2	407.2	416.8	407.6	416.0	406.4	414.4	404.4	417.2	405.2	414.0	402.8
PARLY2	421.4	401.6	423.8	402.8	420.8	404.0	420.2	402.2	417.8	398.0	419.6	399.8	415.4	399.8
BHSQL2	425.0	402.8	428.6	401.6	423.8	401.6	423.8	399.2	422.0	401.0	425.6	399.8	422.6	395.0
DHULE	427.7	403.9	429.7	403.9	427.7	403.9	425.7	401.9	429.7	398.0	431.6	396.0	431.6	396.0
PADGE	423.1	402.5	423.2	404.5	419.8	400.3	424.5	403.7	424.0	406.2	423.6	401.5	421.0	406.3
KARAD2	429.8	413.6	431.0	411.8	429.8	408.2	431.6	410.6	432.2	407.6	428.6	406.4	428.6	408.2