

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	7 June		8 June		9 June		10 June		11 June		12 June		13 June	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	420.2	380.0	416.6	378.8	419.6	387.2	428.0	401.6	428.6	404.6	428.0	404.0	426.8	402.2
KORDY	419.6	406.4	416.4	398.4	418.4	403.6	419.6	407.2	421.2	408.4	418.0	403.6	422.8	405.6
PARLY2	419.6	386.0	415.4	382.4	420.8	389.6	420.2	396.8	426.8	402.8	424.4	396.8	423.8	404.6
BHSQL2	426.2	401.0	423.8	401.6	425.6	402.2	425.6	403.4	431.0	399.8	428.0	402.8	427.4	404.6
DHULE	429.7	396.0	429.7	401.9	433.6	401.9	431.6	405.9	435.6	407.9	429.7	403.9	429.7	403.9
PADGE	419.7	401.2	423.1	402.1	421.5	398.0	421.6	403.7	424.0	408.6	421.5	402.8	422.2	406.7
KARAD2	419.6	392.6	421.4	394.4	420.8	390.8	424.4	398.0	424.4	407.0	425.0	402.2	428.0	407.6