

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	12 July		13 July		14 July		15 July		16 July		17 July		18 July	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	416.6	398.0	417.2	402.8	419.0	399.2	419.0	399.8	419.0	399.2	419.6	399.2	417.8	400.4
KORDY	417.6	408.8	418.4	410.4	418.4	409.6	419.6	410.0	420.8	408.0	420.4	406.0	421.2	411.6
PARLY2	422.6	405.8	424.4	400.4	423.2	401.0	421.4	398.6	425.0	396.8	422.0	393.8	419.0	389.6
BHSQL2	429.8	415.4	430.4	417.2	428.0	411.2	430.4	408.2	431.6	411.2	433.4	410.0	432.8	414.2
DHULE	435.6	411.8	435.6	417.8	431.6	411.8	433.6	405.9	433.6	407.9	435.6	407.9	435.6	409.9
PADGE	427.4	404.6	429.1	405.3	426.6	402.3	427.2	402.8	425.6	405.6	430.5	397.9	425.2	403.0
KARAD2	428.6	406.4	430.4	399.2	428.0	396.2	431.6	398.6	434.6	406.4	435.2	399.2	432.2	397.4