

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.

MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	8 Aug		9 Aug		10 Aug		11 Aug		12 Aug		13 Aug		14 Aug	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	421.4	407	423.2	409.4	427.4	415.4	426.2	412.4	422.6	412.4	425	411.8	422.6	411.2
KORDY	421.2	413.2	423.2	413.2	425.6	418	425.2	414.8	423.2	416.8	425.2	416.8	425.2	414.4
PARLY2	417.8	398.6	420.2	398	424.4	401.6	421.4	400.4	420.2	393.8	420.8	395.6	420.8	396.8
BHSQL2	428.6	413	431.6	409.4	432.2	417.2	432.2	413	438.2	418.4	435.2	419	437	418.4
DHULE	425.7	407.9	431.6	400	431.6	413.8	427.7	403.9	427.7	411.8	427.7	411.8	431.6	411.8
PADGE	419	402.3	418.7	399.2	418.7	400	422	402.1	417.5	406.1	419.4	408.9	423.2	404.1
KARAD2	425	401.6	425.6	405.2	425.6	400.4	424.4	405.2	426.2	405.2	425	405.2	426.8	408.2