

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	10 Oct		11 Oct		12 Oct		13 Oct		14 Oct		15 Oct		16 Oct	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	425.6	410	425	414.2	422.6	413.6	421.4	410.6	422	413.6	422.6	411.8	421.4	411.2
KORDY	425.6	410.4	427.2	411.6	422.4	411.2	420.4	407.6	424.4	409.6	426	406.4	422.4	412
PARLY2	427.4	383.6	429.2	395	424.4	402.2	423.2	401.6	422.6	402.8	424.4	397.4	423.2	395.6
BHSQL2	434.6	400.4	432.2	398	424.4	392	426.2	397.4	427.4	395	440	394.4	431.6	406.4
DHULE	435.6	401.9	433.6	403.9	429.7	401.9	429.7	405.9	429.7	401.9	431.6	401.9	435.6	403.9
PADGE	422	398.7	419.1	397.9	418.6	399.2	423.9	404	424.9	407.9	422.4	400.9	423.2	407.7
KARAD2	429.2	401.6	429.8	407	430.4	406.4	426.8	408.8	428	407	430.4	406.4	431	408.2