

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	7 Nov		8 Nov		9 Nov		10 Nov		11 Nov		12 Nov		13 Nov	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	419	405.2	418.4	398.6	420.2	399.8	425.6	402.2	422	405.2	422	401	414.2	398
KORDY	418	402	418	400.4	419.2	400.4	421.2	406.4	418.8	400.4	416.8	397.2	414.8	403.2
PARLY2	420.8	394.4	419.6	404	422	392	425.6	391.4	423.8	394.4	422	397.4	421.4	395
BHSQL2	422	398.6	423.2	386.6	423.8	383.6	428	407	425	377.6	424.4	381.2	425	396.2
DHULE	427.7	401.9	431.6	400	431.6	398	433.6	407.9	433.6	396	429.7	390.1	425.7	400
PADGE	425.9	405.7	424.4	406.3	425.7	402.7	425.9	405	422	407.7	422.7	403.7	421.5	409.1
KARAD2	427.4	407.6	426.8	405.8	425	406.2	424.5	407.3	426.2	405.6	429.2	401	429.2	408.2