

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	12 Nov	13 Nov	14 Nov	15 Dec	16 Dec	17 Dec	18 Dec
	Max	Min	Max	Min	Max	Min	Max
CHDPR	420.8	400.4	420.2	395	417.8	402.8	420.2
KORDY	416.8	404.4	418.8	403.6	417.2	406	418
PARLY2	423.8	402.8	426.2	398	423.8	403.4	424.4
BHSQL2	425.6	401	429.2	396.8	425	398.6	426.2
DHULE	431.6	400	431.6	401.9	425.7	401.9	429.7
PADGE	422.7	406.1	426.9	402.7	424.3	407.3	426
KARAD2	429.2	410.6	429.8	410.6	429.8	410	433.4