

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	17 Jan		18 Jan		19 Jan		20 Jan		21 Jan		22 Jan		23 Jan	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	420.8	409.4	422	413	422	411.8	420.8	411.8	421.4	408.8	420.2	410.6	420.2	409.4
KORDY	422.8	404	422.4	406.4	422.8	406	423.2	407.2	423.6	405.6	422.8	407.6	421.2	406
PARLY2	419.6	392	420.2	399.8	418.4	395.6	420.8	392.6	422	382.4	417.8	380	418.4	393.8
BHSQL2	428	398	428	393.2	430.4	395.6	430.4	392.6	430.4	397.4	431.6	400.4	428	396.8
DHULE	429.7	401.9	427.7	401.9	433.6	401.9	431.6	401.9	429.7	401.9	429.7	403.9	431.6	405.9
PADGE	422.3	405.6	420.6	404.1	422.4	403.3	422.2	406.3	423.5	407.3	423.9	404	422	407.5
KARAD2	426.8	398.6	423.8	397.4	426.8	404.6	426.8	403.4	426.2	402.2	423.8	392.6	426.2	399.8