

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	14 June		15 June		16 June		17 June		18 June		19 June		20 June	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	426.2	406.4	425.0	400.4	426.8	410.0	428.6	410.0	427.4	407.0	425.0	405.2	426.8	405.2
KORDY	422.0	409.2	421.6	403.2	423.2	410.0	423.6	409.6	422.8	409.6	421.2	410.4	419.6	410.4
PARLY2	421.4	403.4	425.0	402.2	426.8	408.2	427.4	409.4	424.4	402.2	423.2	399.2	426.2	405.2
BHSQL2	425.6	404.6	428.6	396.2	433.4	407.6	433.4	411.2	429.8	410.6	432.8	411.2	428.6	411.2
DHULE	431.6	403.9	433.6	400.0	437.6	405.9	435.6	409.9	429.7	407.9	437.6	409.9	429.7	411.8
PADGE	423.0	407.9	424.8	407.3	425.9	408.3	427.2	408.7	423.1	409.1	424.5	408.1	427.2	410.6
KARAD2	425.0	406.4	428.6	410.6	427.4	410.6	427.4	411.2	425.6	408.2	428.0	408.2	427.4	411.2