

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	18 July		19 July		20 July		21 July		22 July		23 July		24 July	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	427.4	411.2	428	416.6	427.4	415.4	424.4	416	425	414.2	425	407.6	423.2	411.8
KORDY	424.8	413.2	429.6	419.2	428	415.6	426.4	414.8	425.2	415.2	425.6	411.2	422	411.6
PARLY2	425	402.2	427.4	400.4	423.8	399.8	422.6	402.8	423.8	405.2	423.2	398	420.2	403.4
BHSQL2	433.4	413	435.2	421.4	433.4	417.8	434	413.6	436.4	412.4	436.4	413.6	429.8	411.8
DHULE	427.7	403.9	429.7	411.8	427.7	409.9	429.7	409.9	431.6	409.9	431.6	405.9	427.7	403.9
PADGE	421.6	403.7	421.9	405.6	420.6	403.6	420.1	404.1	419.9	404.9	418	400.9	417.7	406.2
KARAD2	428	416	430.4	357.2	429.2	409.4	426.8	410	426.8	412.4	425.6	407.6	425	410.6