

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	16 Aug		17 Aug		18 Aug		19 Aug		20 Aug		21 Aug		22 Aug	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	419.0	407.0	417.2	405.2	411.8	405.2	411.8	405.2	411.8	405.2	415.4	405.1	416.0	405.2
KORDY	420.0	411.2	421.6	410.0	422.4	413.6	421.2	413.2	421.0	409.2	421.2	411.6	422.4	407.6
PARLY2	425.6	405.8	427.4	402.8	427.4	407.0	425.6	408.2	424.4	407.0	423.8	403.4	422.0	402.2
BHSQL2	433.4	415.4	435.2	414.8	435.2	411.2	429.2	410.6	435.2	417.2	437.0	417.2	434.6	411.2
DHULE	431.6	411.8	431.6	411.8	431.6	415.8	431.6	413.8	435.6	415.8	433.6	409.9	431.6	405.9
PADGE	426.3	406.1	422.8	403.7	425.1	404.0	420.1	404.9	424.1	409.0	423.2	403.6	422.0	403.0
KARAD2	433.4	410.0	431.6	404.6	430.4	408.2	429.8	407.0	432.2	405.8	431.0	404.6	429.8	408.8