

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	24 Jan		25 Jan		26 Jan		27 Jan		28 Jan		29 Jan		30 Jan	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	419.6	408.2	420.8	410	420.2	410	420.8	409.4	419.6	408.2	420.2	408.2	419.6	410
KORDY	418.8	403.6	419.6	404.4	424.4	406.8	423.2	404	422.4	406.4	419.6	406.8	420	407.2
PARLY2	416.6	389.6	419	394.4	422	394.4	423.2	392.6	419.6	387.2	416.6	391.4	418.4	393.2
BHSQL2	426.8	389.6	428	393.8	429.8	402.8	431	390.8	430.4	401	427.4	400.4	427.4	397.4
DHULE	429.7	400	427.7	401.9	429.7	401.9	429.7	394	429.7	401.9	429.7	401.9	425.7	400
PADGE	427.8	404.6	423.5	404.2	424.8	411.4	425.5	404.1	420.1	408.9	422.6	406.1	423.2	405.6
KARAD2	426.8	396.8	425.6	398.6	427.4	401	427.4	398	426.2	403.4	424.4	400.4	423.8	397.4