

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	19 Mar		20 Mar		21 Mar		22 Mar		23 Mar		24 Mar		25 Mar	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	414.2	406.4	416.6	398	415.4	399.2	419	401	421.4	405.8	420.8	401.6	420.8	402.8
KORDY	417.2	404.4	419.2	400	416	400.8	419.6	404.8	425.6	410.4	419.6	402.4	420.8	402
PARLY2	422.6	408.2	426.2	400.4	422	402.2	426.2	401.6	432.2	407.6	423.8	397.4	430.4	398.6
BHSQL2	426.8	410.6	431	408.8	427.4	405.2	426.8	410.6	435.2	414.8	431	408.8	432.8	410.6
DHULE	425.7	407.9	429.7	398	429.7	401.9	431.6	405.9	433.6	411.8	429.7	407.9	435.6	411.8
PADGE	418.9	403.6	425.2	404.4	423.6	404.9	424.3	405.6	423.6	408.7	426.9	401.3	425.2	406.7
KARAD2	425	405.2	420	420	424.4	414.2	428.6	408.2	426.2	411.2	425.6	408.2	428	405.8