

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	21 June		22 June		23 June		24 June		25 June		26 June		27 June	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	423.8	402.2	420.8	398.6	426.2	396.2	422.6	405.2	420.8	405.8	427.4	399.2	425.6	406.4
KORDY	421.6	409.6	418.0	406.8	423.2	406.0	420.4	408.8	420.0	408.4	421.2	407.2	423.2	411.2
PARLY2	425.0	399.8	422.0	402.2	423.2	403.4	423.8	402.2	421.4	402.8	422.0	393.8	424.4	398.0
BHSQL2	429.8	408.2	426.8	408.2	432.8	409.4	429.8	408.2	429.2	413.0	428.0	411.2	432.2	408.8
DHULE	433.6	405.9	429.7	403.9	429.7	403.9	431.6	403.9	429.7	407.9	427.7	405.9	433.6	403.9
PADGE	425.3	404.1	420.6	405.2	423.9	406.3	425.2	406.1	425.6	412.1	423.4	407.0	425.6	408.6
KARAD2	430.4	407.6	425.6	408.8	428.6	408.2	428.6	407.0	427.4	411.8	428.0	405.2	428.0	406.4