

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	20 June		21 June		22 June		23 June		10 June		25 June		26 June	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	420.8	408.2	422	411.2	420.8	411.8	422	411.2	420.8	412.4	421.4	407.6	422	412.4
KORDY	422	412	422	413.2	421.6	414	419.6	412.8	420.4	414	422.4	413.6	424.4	410.8
PARLY2	415.4	393.2	416	395	417.8	398.6	419.6	400.4	419.6	397.4	419	395.6	417.8	398
BHSQL2	426.8	409.4	426.2	409.4	425.6	408.8	422	408.2	426.8	408.2	427.4	416	430.4	408.8
DHULE	425.7	401.9	425.7	401.9	423.7	403.9	419.8	403.9	427.7	400	427.7	405.9	427.7	405.9
PADGE	422.7	401.6	422.8	401.6	419.9	401.5	417.3	404.9	420.7	406.7	424.5	401.1	420.6	403.6
KARAD2	426.8	409.4	426.8	408.8	424.4	406.4	422.6	402.2	424.4	406.4	428	406.4	424.4	407