

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	26 Mar		27 Mar		28 Mar		29 Mar		30 Mar		31 Mar		1 Apr	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	417.2	410.1	416.6	398.6	419	399.8	419.6	402.8	422.6	407	419.6	404	423.8	407
KORDY	420	404.3	417.2	401.2	419.2	404	419.6	402.8	422	405.6	420	409.2	423.6	412
PARLY2	428	405.2	423.2	394.4	425.6	397.4	425	395.6	426.8	393.8	423.8	401	428.6	401
BHSQL2	429.8	410.6	426.8	405.2	426.2	406.4	431	404.6	432.8	403.4	429.2	408.8	432.2	406.4
DHULE	429.7	409.9	427.7	403.9	425.7	403.9	427.7	403.9	435.6	405.9	429.7	409.9	429.7	403.9
PADGE	417	404.5	424	401.9	419.9	400.4	421.4	403.3	424.7	406.2	420.8	405.6	423.4	407.5
KARAD2	426.8	407.9	424.4	405.8	427.4	405.2	427.4	404.6	428.6	405.8	425.6	406.4	427.4	405.8