

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.****MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

| Date   | 29 Aug |       | 30 Aug |       | 31 Aug |       | 1 Sep |       | 2 Sep |       | 3 Sep |       | 4 Sep |       |
|--------|--------|-------|--------|-------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|        | Max    | Min   | Max    | Min   | Max    | Min   | Max   | Min   | Max   | Min   | Max   | Min   | Max   | Min   |
| CHDPR  | 427.4  | 416   | 428    | 413   | 423.2  | 413   | 423.8 | 415.4 | 423.8 | 414.2 | 427.4 | 415.4 | 428   | 415.4 |
| KORDY  | 426.4  | 414.8 | 425.6  | 413.2 | 423.2  | 412.8 | 424.4 | 412   | 425.2 | 412.4 | 425.6 | 415.6 | 427.2 | 411.6 |
| PARLY2 | 429.8  | 412.4 | 426.2  | 407   | 426.2  | 406.4 | 426.2 | 412.4 | 427.4 | 407.6 | 426.8 | 407.6 | 427.4 | 409.4 |
| BHSQL2 | 438.8  | 421.4 | 433.4  | 416   | 433.4  | 417.2 | 435.8 | 419.6 | 435.2 | 416   | 437.6 | 417.2 | 435.8 | 410.6 |
| DHULE  | 431.6  | 415.8 | 429.7  | 409.9 | 429.7  | 411.8 | 431.6 | 417.8 | 433.6 | 415.8 | 433.6 | 417.8 | 433.6 | 411.8 |
| PADGE  | 424.9  | 405.3 | 421.9  | 402.3 | 422.2  | 407.8 | 424.5 | 413.2 | 430.2 | 407.7 | 426.3 | 407.5 | 424.7 | 405.4 |
| KARAD2 | 432.2  | 413.6 | 430.4  | 414.8 | 431    | 413.6 | 435.2 | 420.2 | 435.8 | 416   | 435.2 | 414.8 | 432.8 | 414.8 |