

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA**

Weekly Maximum / Minimum Voltages for Major 400 KV Sub Stations

Date	27 Dec		28 Dec		29 Dec		30 Dec		31 Dec		1 Jan		2 Jan	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
CHDPR	419.6	406.4	422	408.8	420.2	410.6	422	408.2	421.4	409.4	420.2	407.6	420.2	406.4
KORDY	422	406.4	423.2	410.8	424.4	410.8	424.4	407.2	421.6	409.6	420.8	408.4	423.2	404.4
PARLY2	420.2	393.2	419.6	399.2	417.2	401	420.2	394.4	417.8	398	419.6	397.4	420.8	394.4
BHSQL2	434	403.4	431	405.8	430.4	405.8	432.2	402.2	426.2	406.4	429.8	401	431	403.4
DHULE	433.6	401.9	429.7	409.9	431.6	405.9	429.7	400	423.7	401.9	427.7	409.9	427.7	401.9
PADGE	424.4	407.4	428.5	407.7	423.9	407.5	424.9	411.8	427.4	415	423.1	412.1	426.6	411.8
KARAD2	429.8	406.4	430.4	406.4	428	403.4	429.2	402.8	426.8	399.2	425.6	401	427.4	400.4