

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 3-Jan-11 TO 9-Jan-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Cent_Sect	NTPC(K-6)	500	2-Dec-10	7:44	5-Jan-11	20:48	Annual Overhaul
Parli	Unit 2	30	11-Dec-10	23:51		Continued.	Annual Overhaul.
Koyna	Unit 9	80	22-Dec-10	07:40	3-Jan-11	11:45	Annual overhaul.
Koradi	Unit 6	210	26-Dec-10	09:23		Continued.	Annual Overhaul.
Khaparkheda	Unit 4	210	3-Jan-11	15:26		Continued.	Capital Overhaul.
Dabhol	3B	230	4-Jan-11	16:44		Continued.	Rehabilitation work.
Dabhol	3B	230	4-Jan-11	16:44		Continued.	Rehabilitation work
Tata	Trombay 6	500	7-Jan-11	00:04		Continued.	Capital overhaul.
Uran	Unit 5	108	7-Jan-11	06:00	7-Jan-11	20:59	Filter replacement work.
Uran	Unit A0	120	7-Jan-11	05:57		Continued.	Main T/F oil leakage attending work.
Koyna	ST-IV 1	250	8-Jan-11	22:00	9-Jan-11	03:30	To Attend Down Stream Seal Servomotor Oil Leakage.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19:00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19:52		Continued.	R.M.Work.
Paras	Unit 2	55	16-Nov-10	23:00		Continued.	Boiler tube validity expired.
Parli	Unit 1	30	15-Dec-10	04:31		Continued.	W/Dn.
Bhusawal	Unit 1	58	15-Dec-10	10:40		Continued.	Coal Mill problem.
Dabhol	1B	230	1-Jan-11	04:21	3-Jan-11	12:50	High exhaust temp.
Bhusawal	Unit 2	210	3-Jan-11	10:25	5-Jan-11	19:49	Boiler Tube Leakage.
Koradi	Unit 2	105	3-Jan-11	09:15	5-Jan-11	08:20	Boiler Tube Leakage.
Dabhol	2A	230	3-Jan-11	10:18	4-Jan-11	11:03	Tripped on Boiler Protection.
Parli	Unit 3	210	4-Jan-11	07:20	4-Jan-11	15:36	Bus Fault at Parli Ext.
Parli	Unit 4	210	4-Jan-11	07:20	4-Jan-11	17:21	Bus Fault at Parli Ext.
Parli	Unit 5	210	4-Jan-11	07:20	4-Jan-11	18:48	Bus Fault at Parli Ext.
Parli	Unit 6	250	4-Jan-11	07:20	4-Jan-11	15:58	Bus Fault at Parli Ext.
Parli	Unit 7	250	4-Jan-11	07:20	4-Jan-11	18:40	Bus Fault at Parli Ext.
Chandrapur	Unit 2	210	5-Jan-11	10:54	5-Jan-11	16:01	LBB Operated at GT-4.
Chandrapur	Unit 4	210	5-Jan-11	10:54	5-Jan-11	20:23	LBB Operated at GT-4.
Chandrapur	Unit 5	500	5-Jan-11	10:54	6-Jan-11	00:54	LBB Operated at GT-4.
Chandrapur	Unit 6	500	5-Jan-11	10:54	5-Jan-11	23:07	LBB Operated at GT-4.
Koyna	Unit 5	80	5-Jan-11	21:17	5-Jan-11	22:01	Turbine Problem.
Koyna	Unit 10	80	5-Jan-11	21:47	6-Jan-11	11:45	Tripped,LA Burst R-Ph.
Chandrapur	Unit 2	210	5-Jan-11	17:12	5-Jan-11	18:53	Low Vaccum.
Chandrapur	Unit 2	210	5-Jan-11	19:51	5-Jan-11	21:48	Steam Temp.Low.
Koyna	Unit 9	80	5-Jan-11	11:59	5-Jan-11	13:10	Tripped due to jerk on PPL-K'gaon line.
Koyna	Unit 10	80	5-Jan-11	11:29	5-Jan-11	12:40	Tripped due to jerk on PPL-K'gaon line.
Chandrapur	Unit 4	210	6-Jan-11	05:27	6-Jan-11	10:31	AVR Fan Trip
Parli	Unit 6	250	6-Jan-11	10:12	6-Jan-11	11:55	Furnance Pressure high
Parli	Unit 7	250	6-Jan-11	23:07	7-Jan-11	01:57	Low Drum Level
Uran	Unit 6	108	6-Jan-11	23:15		Continued.	Tube leakage.
Koyna	Unit 3	75	6-Jan-11	15:45		Continued.	Tripped on mechanical protection
Uran	Unit 7	108	7-Jan-11	19:02	7-Jan-11	20:47	Steam Turbine Prot.Fault
Koradi	Unit 7	210	7-Jan-11	12:48	9-Jan-11	13:49	Water Valve leakage
Uran	Unit 8	108	7-Jan-11	19:02	7-Jan-11	20:20	Steam Turbine Prot.Fault
Uran	Unit B0	120	7-Jan-11	19:02	8-Jan-11	06:17	Steam Turbine Prot.Fault
Koradi	Unit 3	105	7-Jan-11	21:14		Continued.	Withdrawn
Koradi	Unit 4	105	7-Jan-11	22:06		Continued.	Withdrawn
Koradi	Unit 2	105	7-Jan-11	22:11		Continued.	Withdrawn
Koradi	Unit 1	105	7-Jan-11	22:28		Continued.	Withdrawn
Nasik	Unit 3	210	8-Jan-11	03:40	8-Jan-11	07:25	Boiler problem
Nasik	Unit 2	120	8-Jan-11	10:10		Continued.	Boiler Tube Leakage.
Parli	Unit 6	250	8-Jan-11	18:42	9-Jan-11	03:14	High Drum Level.