

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 31-Jan-11 TO 6-Feb-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Koradi	Unit 6	210	26-Dec-10	09.23		Continued.	Annual Overhaul.
Khaparkheda	Unit 4	210	3-Jan-11	15.26		Continued.	Capital Overhaul.
Dabhol	3B	230	4-Jan-11	16.44		Continued.	Rehabilitation work.
Tata	Trombay 6	500	7-Jan-11	00.04	1-Feb-11	13.56	Capital overhaul.
Koyna	Unit 11	80	13-Jan-11	07.45		Continued.	Retrofitting work of excitation system.
Dabhol	3A	230	29-Jan-11	17.35		Continued.	Heavy leakage in CW Duct
Dabhol	3X	290	29-Jan-11	17.35		Continued.	Hand Tripped
Uran	Unit 6	108	5-Feb-11	11.28		Continued.	Stator Earth Fault

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Chandrapur	Unit 6	500	30-Jan-11	14.25	1-Feb-11	11.26	Boiler Tube Leakage.
Nasik	Unit 3	210	31-Jan-11	04.15	31-Jan-11	10.25	Turbine Trip.
Cent_Sect	NTPC(V-7)	500	31-Jan-11	15.47	3-Feb-11	15.07	Boiler Tube Leakage.
Paras	Unit 3	250	31-Jan-11	20.42	4-Feb-11	04.53	Boiler Tube Leakage.
Dabhol	1B	230	31-Jan-11	20.47	1-Feb-11	20.08	Tripped on high spread.
Tata	Trombay 7A	120	31-Jan-11	06:20	31-Jan-11	09:17	Tripped on Control Instrumentation.
Tata	Trombay 7B	60	31-Jan-11	06:20	31-Jan-11	11:20	Tripped on Control Instrumentation.
Tata	Trombay 7A	120	31-Jan-11	21:20	1-Feb-11	08.09	Tripped.
Tata	Trombay 7B	60	31-Jan-11	21:20	1-Feb-11	04.38	Tripped.
Chandrapur	Unit 3	210	1-Feb-11	20.35	4-Feb-11	08.56	Boiler Tube Leakage.
Tata	Trombay 8	250	3-Feb-11	00.24	3-Feb-11	05.44	Tripped on Flame Failure.
Paras	Unit 4	250	3-Feb-11	14.28	3-Feb-11	17.49	Generator Protection Operated.
Parli	Unit 5	210	3-Feb-11	22.00		Continued.	BLR T/L.
Uran	Unit 5	108	4-Feb-11	00.19	4-Feb-11	20.21	Filter replacement.
Parli	Unit 7	250	5-Feb-11	22.27	6-Feb-11	01.09	High Furnace Pressure
Cent_Sect	KARPR1	220	6-Feb-11	00.08		Continued.	Moderator pump tripped
Nasik	Unit 5	210	6-Feb-11	10.10	7-Feb-11	05.50	Heavy steam leakage at PRDS Intake Drain line
Paras	Unit 4	250	6-Feb-11	13.05	6-Feb-11	16.32	Fire protection operated
Chandrapur	Unit 3	210	6-Feb-11	23.51	7-Feb-11	03.25	Low Drum Level