

# GENERATING UNIT OUTAGES FOR THE WEEK

FROM 28-Feb-11 TO 6-Mar-11

## UNIT UNDER PLANNED OUTAGE

| name      | unit_no   | derat_cap | date_trip | time_trip | date_sync | time_sync  | reason                   |
|-----------|-----------|-----------|-----------|-----------|-----------|------------|--------------------------|
| Dabhol    | 3B        | 230       | 4-Jan-11  | 16.44     |           | Continued. | Rehabilitation work.     |
| Dabhol    | 3A        | 230       | 29-Jan-11 | 17.35     | 6-Mar-11  | 00.49      | Heavy leakage in CW Duct |
| Dabhol    | 3X        | 290       | 29-Jan-11 | 17.35     | 6-Mar-11  | 14:24      | Hand Tripped             |
| Cent_Sect | Tarapur 2 | 80        | 4-Mar-11  | 01.25     |           | Continued. | Refueling Work.          |

## UNIT UNDER FORCED OUTAGE

| name       | unit_no    | derat_cap | date_trip | time_trip | date_sync | time_sync  | reason                                   |
|------------|------------|-----------|-----------|-----------|-----------|------------|------------------------------------------|
| Parli      | Unit 6     | 250       | 24-Feb-11 | 18.58     | 28-Feb-11 | 02.21      | Bunkering Problem.                       |
| CPP        | WPCL U-3   | 135       | 25-Feb-11 | 21.09     | 28-Feb-11 | 03.43      | Tripped                                  |
| Tata       | Trombay 8  | 250       | 26-Feb-11 | 01.31     | 28-Feb-11 | 04.52      | Cooling water system                     |
| Koyna      | Unit 5     | 80        | 27-Feb-11 | 07.25     |           | Continued. | Needle replacement                       |
| Nasik      | Unit 1     | 120       | 28-Feb-11 | 03.05     | 28-Feb-11 | 10.40      | Bus Fault                                |
| Nasik      | Unit 2     | 120       | 28-Feb-11 | 03.05     | 28-Feb-11 | 09.55      | Bus Fault                                |
| Nasik      | Unit 3     | 210       | 28-Feb-11 | 03.05     | 28-Feb-11 | 09.55      | Bus Fault                                |
| Nasik      | Unit 4     | 210       | 28-Feb-11 | 03.05     | 1-Mar-11  | 07.35      | Bus Fault                                |
| Nasik      | Unit 5     | 210       | 28-Feb-11 | 03.05     | 28-Feb-11 | 14.40      | Bus Fault                                |
| Parli      | Unit 4     | 210       | 28-Feb-11 | 21.28     | 1-Mar-11  | 02.10      | H2 Cooler Drem Line Leakage.             |
| Koradi     | Unit 7     | 210       | 1-Mar-11  | 07.30     | 3-Mar-11  | 17.54      | Air Preheater Problem.                   |
| Dabhol     | 1A         | 230       | 2-Mar-11  | 02.35     | 2-Mar-11  | 04.04      | Problem in Fuel Gas Pressure @ GAIL End. |
| Dabhol     | 1B         | 230       | 2-Mar-11  | 02.35     | 2-Mar-11  | 07.00      | Problem in Fuel Gas Pressure @ GAIL End. |
| Dabhol     | 1X         | 290       | 2-Mar-11  | 02.35     | 2-Mar-11  | 06.04      | Problem in Fuel Gas Pressure @ GAIL End. |
| Dabhol     | 2A         | 230       | 2-Mar-11  | 02.35     | 2-Mar-11  | 05.14      | Problem in Fuel Gas Pressure @ GAIL End. |
| Dabhol     | 2B         | 230       | 2-Mar-11  | 02.35     | 2-Mar-11  | 15.11      | Problem in Fuel Gas Pressure @ GAIL End. |
| Dabhol     | 2X         | 290       | 2-Mar-11  | 02.35     | 2-Mar-11  | 19.45      | Problem in Fuel Gas Pressure @ GAIL End. |
| Koyna      | UNIT 6     | 75        | 2-Mar-11  | 12.40     | 3-Mar-11  | 07.00      | Bus Fault.                               |
| Koyna      | Unit 7     | 80        | 2-Mar-11  | 12.40     | 3-Mar-11  | 07.00      | Bus Fault.                               |
| Koyna      | Unit 8     | 80        | 2-Mar-11  | 12.40     | 3-Mar-11  | 07.00      | Bus Fault.                               |
| Dabhol     | 2B         | 230       | 2-Mar-11  | 22.28     | 4-Mar-11  | 12.18      | Steam Line Leakage.                      |
| CPP        | JSW (J) U1 | 300       | 3-Mar-11  | 22.31     |           | Continued. | Condenser tube leakage.                  |
| Cent_Sect  | NTPC(K-3)  | 210       | 4-Mar-11  | 13.08     | 5-Mar-11  | 09.53      | Boiler Tube Leakage.                     |
| Uran       | Unit 8     | 108       | 4-Mar-11  | 00.05     | 4-Mar-11  | 18.25      | Filter replacement.                      |
| Bhusawal   | Unit 3     | 210       | 5-Mar-11  | 07.07     | 5-Mar-11  | 09.34      | Coal problem.                            |
| Chandrapur | Unit 3     | 210       | 5-Mar-11  | 14.32     |           | Continued. | UAT Trip.                                |
| Dabhol     | 2A         | 230       | 5-Mar-11  | 13.30     | 5-Mar-11  | 16.00      | Gas heater problem.                      |
| Koyna      | Unit 6     | 75        | 5-Mar-11  | 07.25     |           | Continued. | Turbine drain pipe leakage.              |
| Cent_Sect  | NTPC(V-7)  | 500       | 6-Mar-11  | 18.47     |           | Continued. | Boiler Tube Leakage.                     |
| Paras      | Unit 4     | 250       | 7-Mar-11  | 05.38     |           | Continued. | Boiler Tube Leakage                      |