

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 2-May-11 TO 8-May-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1B	230	15-Mar-11	02.37		Continued.	Upgradation Work.
Khaparkheda	Unit 3	210	25-Apr-11	02.51		Continued.	Annual overhaul.
Cent_Sect	Kawas GT1A	106	5-May-11	09.00		Continued.	Inspection Work.
Cent_Sect	NTPC (V-1)	210	7-May-11	00.46		Continued.	A/OH

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	Tarapur 2	80	26-Apr-11	17.50	2-May-11	00.45	Water Heater outlet Valve problem
Cent_Sect	Kawas GT2A	106	27-Apr-11	12.43	3-May-11	18.28	Preventive maint.work
Parli	Unit 4	210	29-Apr-11	16.58	2-May-11	17.39	I.D.Fan problem.
Bhusawal	Unit 3	210	30-Apr-11	09.02	2-May-11	10.10	Boiler Tube Leakage.
Parli	Unit 6	250	30-Apr-11	20.37	3-May-11	17.26	Boiler Tube Leakage.
Koyna	Unit 11	80	1-May-11	07.00	8-May-11	14.55	Rotor E/F
Bhusawal	Unit 2	210	1-May-11	16.58	3-May-11	13.43	Boiler Tube Leakage
Nasik	Unit 1	120	1-May-11	22.15	2-May-11	01.25	Vaccume Level Low
Paras	Unit 3	250	2-May-11	03.48	2-May-11	07.09	Flame Failure
Cent_Sect	NTPC(V-4)	210	2-May-11	16.23	4-May-11	02.54	Blr T/L.
Cent_Sect	NTPC(K-7)	500	3-May-11	03.18	5-May-11	09.42	6.6KV Bus Flashover.
CPP	JSW (J) U1	300	3-May-11	04.03	3-May-11	08.45	Tripped due to N.Koyna-Jaigad line I&II.
CPP	JSW (J) U2	300	3-May-11	04.03	3-May-11	09.40	Tripped due to N.Koyna-Jaigad line I&II.
Parli	Unit 6	250	4-May-11	12.45	4-May-11	15.58	Furnance Pressure High.
Chandrapur	Unit 2	210	4-May-11	16.19	8-May-11	02.49	Boiler Tube Leakage.
Paras	Unit 3	250	4-May-11	21.41	6-May-11	22.16	Main Steam Line Valve Problem.
Paras	Unit 4	250	6-May-11	14.06	6-May-11	15.55	Loss of Fuel.
Parli	Unit 6	250	7-May-11	03.09	7-May-11	06.14	Furnace pressure high.
Bhusawal	Unit 2	210	8-May-11	10.19		Continued.	BLR T/L.
Koyna	Unit 5	80	8-May-11	06.25	8-May-11	17.30	Bus-Section II Outage at Pophali.
Koyna	Unit 6	75	8-May-11	07.15	8-May-11	17.15	Bus-Section II Outage at Pophali.
Koyna	Unit 7	80	8-May-11	07.45	8-May-11	17.50	Bus-Section II Outage at Pophali.
Koyna	Unit 8	80	8-May-11	07.05	8-May-11	18.00	Bus-Section II Outage at Pophali.
Koyna	ST - IV 3	250	8-May-11	16.45	8-May-11	19.12	Tripped on automation fail