

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 4-Jul-11 TO 10-Jul-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Cent_Sect	NTPC(V-10)	500	15-Jun-11	01.24	10-Jul-11	21.51	C/OH
Parli	Unit 6	250	16-Jun-11	05.50		Continued.	Annual Overhaul
Chandrapur	Unit 7	500	29-Jun-11	21.40		Continued.	COH
Bhusawal	Unit 3	210	5-Jul-11	00.39		Continued.	Feasibility test of ESP.
Koyna	Unit 4	75	7-Jul-11	11:20		Continued.	Runner Replacement Work.
Koradi	Unit 7	210	7-Jul-11	23:50	9-Jul-11	21.18	Boiler Validity Extasion.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	TARAPUR-4	540	30-May-11	20.00	6-Jul-11	00.35	Survilence Test
Uran	Unit 8	108	6-Jun-11	23.12		Continued.	Bus Bar Protection operated,as Y-Ph BKR pole of Uran U-5 burst.
CPP	WPCL U-3	135	20-Jun-11	03.16	4-Jul-11	17.18	Maintenance work.
Tata	Trombay 5	500	4-Jul-11	13.10	4-Jul-11	14.37	Flame/Failure.
Cent_Sect	NTPC(K-5)	500	4-Jul-11	00.31	6-Jul-11	03.05	BTL
Cent_Sect	NTPC(K-3)	210	7-Jul-11	18:30	8-Jul-11	13:00	Boiler Tube Leakage.
Parli	Unit 7	250	7-Jul-11	12:14		Continued.	Boiler Tube Leakage.
Nasik	Unit 3	210	8-Jul-11	05:05	8-Jul-11	17.45	Steam Temp. Low.
Uran	Unit B0	120	8-Jul-11	09.05	9-Jul-11	04.00	Boiler protection operated.
Parli	Unit 4	210	9-Jul-11	13.10		Continued.	Low Condenser Vacum.
CPP	WPCL U-1	135	9-Jul-11	19.30	9-Jul-11	21.22	Unit Tripped.
CPP	WPCL U-3	135	9-Jul-11	21.00	10-Jul-11	05.45	Hydraulic Oil Pump Tripped.
Uran	Unit A0	120	9-Jul-11	07.08	9-Jul-11	15.36	Excitatt on T/F Problem.
Nasik	Unit 4	210	10-Jul-11	11.30		Continued.	Withdrawn due to wet coal.
Uran	Unit B0	120	10-Jul-11	00.45	10-Jul-11	03.04	Boiler Protection.