

GENERATING UNIT OUTAGES FOR THE PERIOD

FROM 2-Jul-12 TO 8-Jul-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Khaparkheda	Unit 2	210	1-Jun-12	05.45		Continued.	Annual overhaul.
Hydro	GHATGHAR	250	5-Jul-12	15.30		Continued.	For AOH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Bhusawal	Unit 4	500	6-Jun-12	06.27		Continued.	Vibration Problem
Paras	Unit 3	250	13-Jun-12	17.05		Continued.	Structure collapse near ESP.
Dabhol	1A	230	16-Jun-12	11.45	5-Jul-12	12.22	Withdrawn.
Koyna	Unit 11	80	18-Jun-12	08.00		Continued.	Stator E/F.
Koyna	ST-IV 2	250	20-Jun-12	11.00	5-Jul-12	16.30	Attending Spherical Valve Servomotor Oil Leakage.
Khaparkheda	Unit 5	500	23-Jun-12	11.09	2-Jul-12	01.27	Bunkering problem.
Parli	Unit 6	250	23-Jun-12	15.03		Continued.	Bunkering problem.
Cent_Sect	NTPC(V-8)	500	23-Jun-12	23.38		Continued.	Boiler tube leakage.
Dabhol	3B	230	25-Jun-12	09.41		Continued.	Gas Shortage
Uran	Unit 5	108	26-Jun-12	12.50	5-Jul-12	18.07	Gas Shortage
Dabhol	2B	230	28-Jun-12	14.44		Continued.	Gas Shortage.
Bhusawal	Unit 3	210	28-Jun-12	23.38	2-Jul-12	06.51	Boiler Validity Expire.
Koyna	Unit 4	75	28-Jun-12	07.10		Continued.	All Injectors Insitu Meter Filling Work.
Parli	Unit 7	250	29-Jun-12	14.45	5-Jul-12	02.53	Furnace pressure high.
Paras	Unit 4	250	30-Jun-12	07.03		Continued.	Main oil tank leakage.
Nasik	Unit 5	210	1-Jul-12	06.40	3-Jul-12	00.23	Tripped on turbine problem.
Parli	Unit 3	210	1-Jul-12	08.09	2-Jul-12	02.38	Tripped on low vaccum.
Cent_Sect	sipat-5	500	2-Jul-12	04.35	2-Jul-12	08.29	Excitor AVR fault.
Bhusawal	Unit 3	210	2-Jul-12	07.20	2-Jul-12	11.06	Tripped.
Bhusawal	Unit 3	210	2-Jul-12	11.20	2-Jul-12	12.52	Low drum level.
Tata	Trombay 8	250	2-Jul-12	21.45	3-Jul-12	08.35	Drum level low.
CPP	JSW (J) U4	300	2-Jul-12	19.06	2-Jul-12	21.46	Drum level high.
Cent_Sect	Sipat-4	500	2-Jul-12	13.15	2-Jul-12	21.46	Boiler tube leakage.
Chandrapur	Unit 5	500	2-Jul-12	13.06	3-Jul-12	12.27	Boiler Tube Leaakage
CPP	WPCL U-2	135	3-Jul-12	01.02	4-Jul-12	18.13	Boiler cleaning.
Chandrapur	Unit 7	500	3-Jul-12	09.19	7-Jul-12	12.10	Boiler Tube Leakage
Cent_Sect	NTPC(K-3)	210	4-Jul-12	23.10	5-Jul-12	20.23	Boiler Tube Leakage
CPP	WPCL U-3	135	5-Jul-12	10.20		Continued.	I.D. FanVibration High.
Cent_Sect	NTPC(K-1)	210	6-Jul-12	00.22	6-Jul-12	05.24	Flame Failure.
Khaparkheda	Unit 5	500	6-Jul-12	01.29	6-Jul-12	03.34	Tripped on generator protection.
CPP	WPCL U-2	135	6-Jul-12	16.15	6-Jul-12	20.06	AC Supply Fail.
Dabhol	1B	230	6-Jul-12	10.27		Continued.	Gas Shortage.
Nasik	Unit 3	210	7-Jul-12	13.35		Continued.	E-Valve 31,heavy leakage.
Uran	Unit 8	108	7-Jul-12	14.28		Continued.	Due to gas shortage.
Bhusawal	Unit 2	210	7-Jul-12	22.34	8-Jul-12	02.26	Flame failure.
Koyna	Unit 9	80	8-Jul-12	08.00	8-Jul-12	11.00	R.M.Work
Khaparkheda	Unit 5	500	8-Jul-12	23.48		Continued.	Flame Failure.