

GENERATING UNIT OUTAGES FOR THE PERIOD

FROM 2-Aug-10 TO 8-Aug-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Chandrapur	Unit 3	210	26-May-10	23.59		Continued.	Water Balancing Problem.
Cent_Sect	Kawas ST2C	116	1-Jul-10	00.08		Continued.	Annual Overhaul.
Parli	Unit 4	210	5-Jul-10	09.27		Continued.	Capital Overhaul
Koyna	ST-IV 1	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST-IV 2	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 3	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 4	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Tata	Trombay 7A	120	25-Jul-10	17.39	2-Aug-10	19.37	Main T/F replacement
Tata	Trombay 7B	60	25-Jul-10	15.45	3-Aug-10	17.06	Inspection and Maint.Work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 3	210	31-Jul-10	05.26		Continued.	AOH.
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Paras	Unit 2	55	13-Jun-10	17.35	7-Aug-10	07.11	For Scrapping.
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	1B	230	18-Jun-10	13.09	4-Aug-10	02.10	Unit Differential.
Dabhol	1A	230	18-Jun-10	13.09	6-Aug-10	10.33	Unit Differential.
Dabhol	1X	290	18-Jun-10	13.09	4-Aug-10	23.21	Unit Differential.
Parli	Unit 2	30	18-Jun-10	06:26		Continued.	For Scrapping.
Parli	Unit 1	30	18-Jun-10	12:11		Continued.	For Scrapping.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Dabhol	2B	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Dabhol	2X	290	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Koradi	Unit 2	105	28-Jul-10	11.31	5-Aug-10	19.54	Bunkering Problem.
Koradi	Unit 5	200	30-Jul-10	08.41	2-Aug-10	17.49	BLR T/L.
Parli	Unit 6	250	31-Jul-10	15.29	2-Aug-10	22.16	Economiser Tube Leakage.
Bhusawal	Unit 1	58	31-Jul-10	19.25	7-Aug-10	00.55	Wet coal problem.
Nasik	Unit 4	210	1-Aug-10	01.15	4-Aug-10	03.40	BTL.
Parli	Unit 7	250	2-Aug-10	06.06	2-Aug-10	09.34	Tripped on flame failure.
Uran	Unit 5	108	2-Aug-10	14.59	2-Aug-10	17.55	Hydac Problem.

Parli	Unit 7	250	2-Aug-10	19.32	3-Aug-10	01.35	Furnace Main Steam Temp.Pressure Low.
Koradi	Unit 7	210	3-Aug-10	21.33	6-Aug-10	04.53	Boiler Tube Leakage.
Chandrapur	Unit 4	210	3-Aug-10	14.52	3-Aug-10	19.54	Rotor Axial High.
Dabhol	1B	230	4-Aug-10	03.30	4-Aug-10	04.35	Trip.(Spread High)
Dabhol	1X	290	4-Aug-10	23.35	5-Aug-10	04.29	Trip.
Koradi	Unit 6	210	4-Aug-10	03.30	4-Aug-10	13.50	Trip.(Muddy Coal)
Parli	Unit 7	250	4-Aug-10	19.14	6-Aug-10	08.14	Steam Temp.Low.
Khaparkheda	Unit 3	210	4-Aug-10	20.10	5-Aug-10	02.00	Furnace Pressure High.
Nasik	Unit 3	210	4-Aug-10	15.00	4-Aug-10	18.50	Boiler Trip.
Nasik	Unit 4	210	4-Aug-10	21.50	5-Aug-10	14.10	Boiler Drain Line Problem.
Cent_Sect	NTPC(K-1)	210	4-Aug-10	12.39	4-Aug-10	17.45	P A Fan Trip.
Dabhol	1B	230	5-Aug-10	07.29	6-Aug-10	05.46	Trip high exhaust spread.
Dabhol	1X	290	5-Aug-10	07.30	6-Aug-10	08.47	Tripped on high exhaust spread.
Koradi	Unit 4	105	5-Aug-10	10.02		Continued.	Condensor tube leakage.
Paras	Unit 4	250	5-Aug-10	11.27	5-Aug-10	13.11	Boiler drum level high.
Bhusawal	Unit 2	210	5-Aug-10	22.08	7-Aug-10	16.33	Economiser tube leakage.
Chandrapur	Unit 6	500	5-Aug-10	23.02	6-Aug-10	08.12	Flame failure.
Cent_Sect	TARAPUR-4	540	5-Aug-10	11.15	7-Aug-10	12.32	Process disturbance problem.
Chandrapur	Unit 4	210	6-Aug-10	11.22	6-Aug-10	18.04	Furnance pressure high.
Dabhol	1B	230	7-Aug-10	05.57	7-Aug-10	14.34	W/DN.
Koradi	Unit 6	210	7-Aug-10	08.15		Continued.	W/DN for fire near wind box.
Bhusawal	Unit 1	58	7-Aug-10	07.00	7-Aug-10	10.15	Wet coal problem.
Parli	Unit 7	250	7-Aug-10	12.05	7-Aug-10	16.13	Furnance pressure low.
Paras	Unit 3	250	7-Aug-10	08.32	8-Aug-10	03.38	Bunkering problem.
Bhusawal	Unit 2	210	7-Aug-10	16.58	7-Aug-10	21.05	Low vaccum.
Dabhol	1A	230	8-Aug-10	03.01	9-Aug-10	00.01	Tripped.
Khaparkheda	Unit 4	210	8-Aug-10	17.26		Continued.	Generator problem
Paras	Unit 4	250	8-Aug-10	10.43		Continued.	Bunkering Problem