

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 3-Oct-11 TO 9-Oct-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Chandrapur	Unit 4	210	16-Aug-11	00.04		Continued.	Annual Overhaul.
Bhusawal	Unit 2	210	22-Aug-11	15.27		Continued.	Annual Overhaul
Parli	Unit 4	210	31-Aug-11	01.07		Continued.	Annual Overhaul.
Dabhol	1B	230	5-Sep-11	23.57		Continued.	Generator Inspection
Cent_Sect	NTPC(K-4)	500	8-Sep-11	14.26		Continued.	Annual Overhaul
Cent_Sect	NTPC(V-5)	210	14-Sep-11	00.41	3-Oct-11	04.19	Annual Overhaul.
Bhusawal	Unit 4	0	5-Oct-11	21.45	6-Oct-11	04.20	Tripped.
Bhusawal	Unit 4	0	6-Oct-11	11.54		Continued.	Outage.
Koradi	Unit 7	210	8-Oct-11	23.43		Continued.	Annual overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
CPP	WPCL U-2	135	11-Sep-11	08.12	5-Oct-11	6:56	Withdrawn
Cent_Sect	NTPC(K-7)	500	14-Sep-11	21.37		Continued.	GT Inspection work
Parli	Unit 7	250	24-Sep-11	18.53		Continued.	Main steam temp.low.
Cent_Sect	NTPC (V-1)	210	24-Sep-11	15.16		Continued.	Coal bunkering problem.
Cent_Sect	NTPC(V-4)	210	24-Sep-11	18.58	9-Oct-11	07.56	Coal bunkering problem.
Cent_Sect	NTPC(V-3)	210	24-Sep-11	16.45		Continued.	Coal bunkering problem.
Cent_Sect	NTPC (K-2)	210	27-Sep-11	03.09	8-Oct-11	05.39	Trip.
Khaparkheda	Unit 2	210	2-Oct-11	16.15	5-Oct-11	02.53	Boiler tube leakage.
Khaparkheda	Unit 5	500	2-Oct-11	03.07	9-Oct-11	22.05	Air Heater Problem
Cent_Sect	NTPC(V-2)	210	3-Oct-11	17.32		Continued.	Coal Shortage.
Nasik	Unit 3	210	3-Oct-11	02.20	3-Oct-11	18.35	Tripped on main steam Temp.low.
Nasik	Unit 4	210	4-Oct-11	03.15	8-Oct-11	05.30	Boiler Tube Leakage.
Koyna	Unit 9	80	4-Oct-11	22.50	4-Oct-11	23.30	Failure of Aux. Supply.
Koyna	Unit 10	80	4-Oct-11	22.50	4-Oct-11	23.30	Failure of Aux. Supply.
Koyna	Unit 11	80	4-Oct-11	22.50	4-Oct-11	23.30	Failure of Aux. Supply.
Koyna	Unit 12	80	4-Oct-11	22.50	4-Oct-11	23.30	Failure of Aux. Supply.
Bhusawal	Unit 4	0	5-Oct-11	12.00	5-Oct-11	18.42	Tripped.
CPP	WPCL U-3	135	5-Oct-11	19.00	8-Oct-11	16.40	W/Dn.
Bhusawal	Unit 4	0	5-Oct-11	00.44	5-Oct-11	03.55	Tripped on turbine prob.
Khaparkheda	Unit 2	210	6-Oct-11	14.58	8-Oct-11	09.24	Boiler Tube Leakage.
Paras	Unit 4	250	6-Oct-11	18.47		Continued.	Bunkering problem.
Cent_Sect	Tarapur 1	80	6-Oct-11	09.39	8-Oct-11	08.27	Under Voltage.
Koyna	ST-IV 2	250	6-Oct-11	21.30		Continued.	Servo motor problem.
Koradi	Unit 6	210	7-Oct-11	16.01	7-Oct-11	17.12	Flame failure.
Nasik	Unit 3	210	7-Oct-11	22.42	10-Oct-11	00.30	Steem leakage.
Koradi	Unit 6	210	8-Oct-11	08.52		Continued.	ID fan problem.
Cent_Sect	Sipat-4	500	8-Oct-11	20.44		Continued.	Boiler tube leakage.
Cent_Sect	NTPC(V-8)	500	9-Oct-11	19.37	9-Oct-11	22.58	FD Fan Problem
Koyna	Unit 12	80	10-Oct-11	05.08		Continued.	B phase Conductor snapped of Pedambe-Karad line
Koyna	Unit 11	80	10-Oct-11	05.08		Continued.	B phase Conductor snapped of Pedambe-Karad line