

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 29-Nov-10 TO 5-Dec-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Parli	Unit 5	210	19-Nov-10	01.05		Continued.	Annual Overhaul
Cent_Sect	NTPC(V-3)	210	23-Nov-10	00.20		Continued.	Annual overhaul.
Nasik	Unit 2	120	23-Nov-10	00.40		Continued.	Annual Overhaul.
REL	1	250	24-Nov-10	03.55		Continued.	Annual overhaul
Koyna	Unit 7	80	25-Nov-10	07.05	29-Nov-10	08.35	Turbine Guide Bearing repl.work
Cent_Sect	NTPC(K-6)	500	2-Dec-10	7:44		Continued.	Annual Overhaul

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Paras	Unit 2	55	16-Nov-10	23.00		Continued.	Boiler tube validity expired.
Koradi	Unit 1	105	25-Nov-10	12.46	1-Dec-10	11.25	Boiler Feed Pump problem
CPP	JSW_JAIGAD	300	25-Nov-10	21.35	4-Dec-10	13.00	Boiler Tube Leakage.
Nasik	Unit 1	120	26-Nov-10	17.50		Continued.	Governig system problem.
Cent_Sect	NTPC(K-5)	500	26-Nov-10	16.33	30-Nov-10	04.09	Boiler Tube Leakage.
Cent_Sect	NTPC(V-4)	210	27-Nov-10	12.07	30-Nov-10	07.54	Boiler Tube Leakage.
Parli	Unit 6	250	28-Nov-10	15.25	1-Dec-10	11.25	BLR T/L.
Cent_Sect	NTPC (K-2)	210	28-Nov-10	20.30	30-Nov-10	09.52	BLR T/L.
Cent_Sect	TARAPUR-4	540	29-Nov-10	13.35		Continued.	Testing work.
Cent_Sect	NTPC(K-4)	500	29-Nov-10	17.38	30-Nov-10	04.08	Bus fault at Korba.
Paras	Unit 3	250	30-Nov-10	02.36	1-Dec-10	08.18	Air heater problem.
Dabhol	1B	230	30-Nov-10	08.34	30-Nov-10	18.34	Emergency push button problem.
Koyna	Unit 2	75	1-Dec-10	07.05	1-Dec-10	20.35	Preventive maintenance work.
Koradi	Unit 2	105	1-Dec-10	22.28	4-Dec-10	10.59	CHP Field problem.
Koyna	Unit 8	80	2-Dec-10	07.05	2-Dec-10	17.45	R.M.Work
Koyna	Unit 11	80	2-Dec-10	08.00	4-Dec-10	01.10	Bearing work.
Khaparkheda	Unit 4	210	3-Dec-10	04.47	4-Dec-10	18.39	Boiler tube leakage.
Nasik	Unit 3	210	3-Dec-10	22.00	6-Dec-10	02.55	Boiler Tube Leakage.
Tata	Trombay 7B	60	4-Dec-10	13.44	4-Dec-10	23.57	Turbine Vibration Balancing.
Dabhol	1B	230	4-Dec-10	22.58	5-Dec-10	08.36	Air Filter Replacement.
Tata	Trombay 7B	60	5-Dec-10	12.32	5-Dec-10	15.28	Balancing Shaft