

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 7-Mar-11 TO 13-Mar-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	3B	230	4-Jan-11	16:44	9-Mar-11	06:04	Rehabilitation work.
Cent_Sect	Tarapur 2	80	4-Mar-11	01:25		Continued.	Refueling Work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Koyna	Unit 5	80	27-Feb-11	07:25	7-Mar-11	16:20	Needle replacement
CPP	JSW (J) U1	300	3-Mar-11	22:31	7-Mar-11	10:38	Condenser Tube leakage.
Chandrapur	Unit 3	210	5-Mar-11	14:32	12-Mar-11	04:35	UAT Trip.
Koyna	Unit 6	75	5-Mar-11	07:25	7-Mar-11	14:40	Turbine drain pipe leakage.
Cent_Sect	NTPC(V-7)	500	6-Mar-11	18:47	8-Mar-11	14:01	Boiler Tube Leakage.
Paras	Unit 4	250	7-Mar-11	05:38	10-Mar-11	08:26	Boiler Tube Leakage
Dabhol	3A	230	7-Mar-11	15:26	7-Mar-11	18:36	Tripped during Testing
Dabhol	3X	290	7-Mar-11	15:24	7-Mar-11	19:27	Tripped during Testing
CPP	WPCL U-3	135	8-Mar-11	00:56	8-Mar-11	04:42	Tripped
Dabhol	1A	230	8-Mar-11	21:37	9-Mar-11	02:06	Due to Control Supply Problem.
Nasik	Unit 1	120	9-Mar-11	09:25	12-Mar-11	15:20	Boiler tube leakage.
CPP	WPCL U-1	135	9-Mar-11	00:00	11-Mar-11	21:33	Filter Work.
Dabhol	3B	230	9-Mar-11	06:39	11-Mar-11	17:34	Test Charge. (for Natural Cooling)
Parli	Unit 6	250	10-Mar-11	17:55	10-Mar-11	20:18	High furnace pressure.
CPP	WPCL U-2	135	10-Mar-11	14:18	10-Mar-11	17:22	Tripped.
Koyna	ST - IV 4	250	10-Mar-11	22:35	11-Mar-11	05:45	Leakage of spherical valve water closing line.
Uran	Unit 5	108	11-Mar-11	01:35		Continued.	Filter replacement
Dabhol	3A	230	12-Mar-11	03:10		Continued.	Gas restriction.
Bhusawal	Unit 3	210	12-Mar-11	04:37	12-Mar-11	10:48	FD fan problem.
Koradi	Unit 5	200	13-Mar-11	09:26		Continued.	PA Fan Tripped
Koyna	ST-IV 2	250	13-Mar-11	10:50	13-Mar-11	18:00	Spherical assembly leakage
Nasik	Unit 5	210	14-Mar-11	04:25		Continued.	HP Control Valve replacement