

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 11-Apr-11 TO 17-Apr-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1B	230	15-Mar-11	02.37		Continued.	Upgradation Work.
Cent_Sect	NTPC(K-3)	210	31-Mar-11	23.46		Continued.	Annual Overhaul
Cent_Sect	sipat-5	500	1-Apr-11	00.14		Continued.	Annual Overall.
Cent_Sect	NTPC(V-4)	210	10-Apr-11	00.01		Continued.	Annual overhaul.
Koyna	Unit 7	80	13-Apr-11	07.05	13-Apr-11	18.45	Preventive Maintenance.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	2A	230	8-Apr-11	17.40	11-Apr-11	13.37	Fine protection system trouble.
Cent_Sect	NTPC(K-7)	500	10-Apr-11	07.45	12-Apr-11	02.56	Boiler tube leakage.
Nasik	Unit 1	120	10-Apr-11	22.50	14-Apr-11	17.35	Boiler tube leakage.
CPP	WPCL U-1	135	11-Apr-11	13.32	11-Apr-11	21.33	For attending Pin hole switch impulse line of LP
Chandrapur	Unit 2	210	11-Apr-11	10.33	14-Apr-11	02.00	Economiser Tube Leakage
Chandrapur	Unit 7	500	12-Apr-11	04.57	16-Apr-11	19.22	Boiler Tube Leakage
Dabhol	1A	230	13-Apr-11	04.47	13-Apr-11	07.19	Drum Level Problem
Dabhol	1X	290	13-Apr-11	04.50	13-Apr-11	08.15	Drum Level Problem
Dabhol	1A	230	13-Apr-11	23.18	14-Apr-11	04.50	Inlet Air Filter Replacement.
Dabhol	1X	290	13-Apr-11	23.18	14-Apr-11	07.52	Due to Non Availability of 1A & 1B.
Chandrapur	Unit 2	210	14-Apr-11	02.56	14-Apr-11	07.22	Low Condenser Vaccume.
Cent_Sect	NTPC (K-2)	210	14-Apr-11	02.18	15-Apr-11	01.45	Boiler Tube Leakage.
Koyna	ST - IV 3	250	15-Apr-11	00.10	15-Apr-11	13.34	Exition Minor Fault.
Bhusawal	Unit 3	210	15-Apr-11	16.09	17-Apr-11	09.36	Boiler Tube Leakage.
Chandrapur	Unit 1	210	15-Apr-11	23.45	16-Apr-11	14.37	Occurrence at 400KV Chandrapur
Chandrapur	Unit 2	210	15-Apr-11	23.45	16-Apr-11	12.37	Occurrence at 400KV Chandrapur
Chandrapur	Unit 3	210	15-Apr-11	23.49	16-Apr-11	12.25	Occurrence at 400KV Chandrapur
Chandrapur	Unit 4	210	15-Apr-11	23.56		Continued.	Occurrence at 400KV Chandrapur
Chandrapur	Unit 6	500	15-Apr-11	23.56	16-Apr-11	07.11	Occurrence at 400KV Chandrapur
CPP	WPCL U-1	135	16-Apr-11	00.44	16-Apr-11	11.23	Maintenance work.
CPP	WPCL U-2	135	16-Apr-11	00.44	17-Apr-11	03.43	Maintenance work.
Chandrapur	Unit 5	500	16-Apr-11	00.10	16-Apr-11	08.01	Occurance at 400KV Chandrapur
Koyna	ST - IV 4	250	16-Apr-11	00.27	16-Apr-11	01.08	Bearing temperature very high.
CPP	WPCL U-1	135	16-Apr-11	21.00		Continued.	Suspected boiler tube leakage.
Cent_Sect	NTPC(V-7)	500	16-Apr-11	17.35	17-Apr-11	20.26	Boiler tube leakage.
Uran	Unit B0	120	16-Apr-11	18.51	16-Apr-11	22.45	Vibration problem.