

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 9-May-11 TO 15-May-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1B	230	15-Mar-11	02.37		Continued.	Upgradation Work.
Khaparkheda	Unit 3	210	25-Apr-11	02.51		Continued.	Annual overhaul.
Cent_Sect	Kawas GT1A	106	5-May-11	09.00	12-May-11	07.59	Inspection Work.
Cent_Sect	NTPC (V-1)	210	7-May-11	00.46		Continued.	A/OH
Cent_Sect	NTPC(K-5)	500	10-May-11	00.00		Continued.	Annual Overhaul
CPP	JSW (J) U1	300	12-May-11	00.24		Continued.	Annual Overhaul.
Koyna	Unit 10	80	13-May-11	00.00		Continued.	Annual Overhaul

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 2	210	8-May-11	10.19	10-May-11	19.40	BLR T/L.
Parli	Unit 7	250	9-May-11	07.39	9-May-11	10.37	Flame failure.
Cent_Sect	NTPC(K-7)	500	11-May-11	01.15		Continued.	Fire in GT
Dabhol	3A	230	11-May-11	16.18	11-May-11	19.37	Power Supply Disturnance.
Dabhol	3B	230	11-May-11	17.14	12-May-11	06.02	Power Supply Disturnance.
Dabhol	3X	290	11-May-11	17.15	11-May-11	20.28	Power Supply Disturnance.
Khaparkheda	Unit 4	210	11-May-11	07.25	11-May-11	11.28	Reheatear Protection Operated.
Khaparkheda	Unit 4	210	11-May-11	12.06	11-May-11	13.56	Drum Level Low.
Koyna	ST - IV 4	250	11-May-11	16.23	12-May-11	18.10	Stator Earth Fault
Dabhol	3B	230	12-May-11	07.59	12-May-11	10.32	Combution valve problem
CPP	WPCL U-3	135	13-May-11	08.23	13-May-11	09.25	P A Fan Problem.
Parli	Unit 5	210	13-May-11	23.43		Continued.	H P Heater Tube Leakage.
Parli	Unit 7	250	15-May-11	07.04		Continued.	Due to CHP Problem.