

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 9-Jul-12 TO 15-Jul-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Khaparkheda	Unit 2	210	1-Jun-12	05.45		Continued.	Annual overhaul.
Hydro	GHATGHAR	250	5-Jul-12	15.30		Continued.	For AOH.
Nasik	Unit 5	210	12-Jul-12	00.35		Continued.	Annual Overhaul
Koradi	Unit 6	210	12-Jul-12	23.56		Continued.	Boiler Validity expired.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Bhusawal	Unit 4	500	6-Jun-12	06.27	10-Jul-12	02.03	Vibration Problem
Paras	Unit 3	250	13-Jun-12	17.05	16-Jul-12	01.03	Structure collapse near ESP.
Koyna	Unit 11	80	18-Jun-12	08.00		Continued.	Stator E/F.
Parli	Unit 6	250	23-Jun-12	15.03	11-Jul-12	02.18	Bunkering problem.
Cent_Sect	NTPC(V-8)	500	23-Jun-12	23.38		Continued.	Boiler tube leakage.
Dabhol	3B	230	25-Jun-12	09.41		Continued.	Gas Shortage
Dabhol	2B	230	28-Jun-12	14.44	10-Jul-12	11.30	Gas Shortage.
Koyna	Unit 4	75	28-Jun-12	07.10		Continued.	All Injectors Insitu Meter Filling Work.
Paras	Unit 4	250	30-Jun-12	07.03	9-Jul-12	15.05	Main oil tank leakage.
CPP	WPCL U-3	135	5-Jul-12	10.20	9-Jul-12	16.56	I.D. FanVibration High.
Dabhol	1B	230	6-Jul-12	10.27		Continued.	Gas Shortage.
Nasik	Unit 3	210	7-Jul-12	13.35	11-Jul-12	05.15	E-Valve 31,heavy leakage.
Uran	Unit 8	108	7-Jul-12	14.28	15-Jul-12	21.10	Due to gas shortage.
Khaparkheda	Unit 5	500	8-Jul-12	23.48	12-Jul-12	18.08	Flame Failure.
Parli	Unit 4	210	9-Jul-12	20.30	10-Jul-12	01.20	Furnace pressure low.
Bhusawal	Unit 3	210	9-Jul-12	23.42	12-Jul-12	21.30	Boiler problem.
Bhusawal	Unit 4	500	10-Jul-12	11.57	10-Jul-12	15.56	Boiler Trip
Dabhol	2A	230	10-Jul-12	17.28		Continued.	Gas Shortage
Uran	Unit 5	108	10-Jul-12	21.35	12-Jul-12	17.16	Gas Shortage
Parli	Unit 6	250	11-Jul-12	07.24	11-Jul-12	11.13	Air Flow pressure High
Cent_Sect	Sipat-4	500	11-Jul-12	18.46	12-Jul-12	18.00	Boiler Tube Leakage
Parli	Unit 3	210	13-Jul-12	02.54		Continued.	P A Fan problem.
Nasik	Unit 3	210	13-Jul-12	06.55	13-Jul-12	08.20	Turbine tripped.
Cent_Sect	Sipat U-2	660	13-Jul-12	01.17	14-Jul-12	23.23	BLR T/L.
Khaparkheda	Unit 5	500	13-Jul-12	15.45	13-Jul-12	21.05	Flame Failure.
Uran	Unit 6	108	13-Jul-12	22.00		Continued.	Gas Shortage
Bhusawal	Unit 4	500	14-Jul-12	02.25	14-Jul-12	09.47	Station T/F trip.
Dabhol	2B	230	14-Jul-12	23.01		Continued.	Gas Shortage
Dabhol	2X	290	14-Jul-12	22.55		Continued.	Gas Shortage
Bhusawal	Unit 4	500	14-Jul-12	18.14	15-Jul-12	03.02	Drum Level High.
Koyna	ST - IV 3	250	14-Jul-12	22.51	14-Jul-12	23.45	Governor isolation valve not operating.
CPP	JSW (J) U1	300	15-Jul-12	18.44		Continued.	On cooling water problem.