

GENERATING UNIT OUTAGES FOR THE PERIOD

FROM 9-Aug-10 TO 15-Aug-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Chandrapur	Unit 3	210	26-May-10	23.59	17-Aug-10	14.51	Water Balancing Problem.
Cent_Sect	Kawas ST2C	116	1-Jul-10	00.08	17-Aug-10	14.11	Annual Overhaul.
Parli	Unit 4	210	5-Jul-10	09.27		Continued.	Capital Overhaul
Koyna	ST-IV 1	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST-IV 2	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 3	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 4	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Bhusawal	Unit 3	210	31-Jul-10	05.26		Continued.	Annual Overhaul.
Cent_Sect	KARPR2	220	14-Aug-10	14:16		Continued.	Annual Overhaul.
Cent_Sect	NTPC(V-8)	500	20-Aug-10	00.46		Continued.	AOH.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Parli	Unit 2	30	18-Jun-10	06:26	14-Aug-10	02.13	For Scrapping.
Parli	Unit 1	30	18-Jun-10	12:11		Continued.	For Scrapping.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Dabhol	2B	230	12-Jul-10	01.55		Continued.	Tripped due to Elect.Fault
Dabhol	2X	290	12-Jul-10	01.55		Continued.	Tripped due to Elect.Fault
Koradi	Unit 4	105	5-Aug-10	10.02	23-Aug-10	09.25	Condensor tube leakage.
Koradi	Unit 6	210	7-Aug-10	08.15	9-Aug-10	19.40	W/DN for fire near wind box.
Dabhol	1A	230	8-Aug-10	03.01	9-Aug-10	00.01	Tripped.
Khaparkheda	Unit 4	210	8-Aug-10	17.26	10-Aug-10	18.45	Generator problem
Paras	Unit 4	250	8-Aug-10	10.43	10-Aug-10	20.20	Bunkering Problem
Paras	Unit 2	55	9-Aug-10	08.30	9-Aug-10	10.33	Low Vaccume
Nasik	Unit 4	210	9-Aug-10	01.15	10-Aug-10	22.08	BLR T/L.
Bhusawal	Unit 1	58	10-Aug-10	06.05	23-Aug-10	08.31	Wet Coal
Tata	Trombay 5	500	10-Aug-10	20.56	10-Aug-10	23.14	F D Fan Trip.

Koradi	Unit 5	200	10-Aug-10	21:32	12-Aug-10	07:57	Furnace Pressure High.
Tata	Trombay 5	500	11-Aug-10	01:52	11-Aug-10	10:18	F D Fan Trip.
Cent_Sect	Sipat-4	500	11-Aug-10	04:56	11-Aug-10	13:30	Generation Protection Operated.
Nasik	Unit 2	120	11-Aug-10	12:45	14-Aug-10	08:15	Heavy Fuel Leakage.
Nasik	Unit 5	210	11-Aug-10	11:13	13-Aug-10	07:40	Cooling Tower Header Leakage.
Paras	Unit 3	250	11-Aug-10	09:25	12-Aug-10	04:57	Bunkering Problem.
Koradi	Unit 2	105	11-Aug-10	11:46	13-Aug-10	13:16	Boiler Tube Leakage.
Parli	Unit 7	250	12-Aug-10	00:05	13-Aug-10	19:22	Furnace Pressure High.
Nasik	Unit 1	120	12-Aug-10	04:30	13-Aug-10	00:40	A/C Supply Failed.
Khaparkheda	Unit 1	210	12-Aug-10	19:42	12-Aug-10	23:13	Furnance pressure high.
Tata	Trombay 5	500	12-Aug-10	09:55	18-Aug-10	06:01	Boiler tube leakage.
Cent_Sect	NTPC(V-5)	210	12-Aug-10	17:30	13-Aug-10	20:50	Boiler tube leakage
Nasik	Unit 1	120	13-Aug-10	02:35	13-Aug-10	07:25	W/Dn. BFP problem.
Parli	Unit 5	210	13-Aug-10	21:07	16-Aug-10	19:47	Furnance pressure high.
Khaparkheda	Unit 3	210	13-Aug-10	16:58	14-Aug-10	20:12	Boiler Tube Leakage.
Nasik	Unit 3	210	14-Aug-10	04:50	14-Aug-10	09:00	Furnace pressure high.
Koradi	Unit 6	210	14-Aug-10	04:17	14-Aug-10	08:47	Furnace pressure high.
Nasik	Unit 4	210	14-Aug-10	06:35	14-Aug-10	10:00	Furance Pressure high.
Paras	Unit 4	250	14-Aug-10	11:40	16-Aug-10	05:34	Bunkering problem.
Khaparkheda	Unit 2	210	14-Aug-10	22:08	16-Aug-10	20:29	Boiler Tube Leakage.
Parli	Unit 3	210	15-Aug-10	05:20	15-Aug-10	12:53	Boiler Trip.
Cent_Sect	NTPC(V-7)	500	15-Aug-10	02:03	16-Aug-10	11:46	Boiler Tube Leakage.
Koradi	Unit 3	105	15-Aug-10	14:26		Continued.	Tripped due to LT supply fail
Parli	Unit 7	250	15-Aug-10	15:35	15-Aug-10	20:13	Reheater protection operated
Parli	Unit 3	210	15-Aug-10	22:55	16-Aug-10	04:12	Furnace Pressure high.
Paras	Unit 2	55	15-Aug-10	23:33	16-Aug-10	06:02	Tripped due to Wet Coal