

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 8-Aug-11 TO 14-Aug-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Dabhol	1A	230	20-May-11	13:22		Continued.	Rotor replacement.
Chandrapur	Unit 7	500	29-Jun-11	21:40		Continued.	COH
Tata	Trombay 8	250	15-Jul-11	01:45		Continued.	AOH
Cent_Sect	NTPC(V-7)	500	18-Jul-11	00:03	13-Aug-11	06:02	Annual overhaul.
Nasik	Unit 3	210	23-Jul-11	01:55		Continued.	Annual Overhaul.
CPP	WPCL U-4	135	24-Jul-11	06:40		Continued.	Maint.Work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 5	108	15-Jul-11	10:40	13-Aug-11	17:05	Turbine Blade Replacement.
Parli	Unit 6	250	1-Aug-11	02:47	8-Aug-11	02:43	I D Fan Problem.
Parli	Unit 3	210	2-Aug-11	12:43		Continued.	Due to wet coal.
Parli	Unit 5	210	5-Aug-11	22:07	12-Aug-11	21:44	Wet coal problem.
Khaparkheda	Unit 5	500	5-Aug-11	09:32		Continued.	H.P.Pump problem
Koyna	Unit 5	80	6-Aug-11	04:05	8-Aug-11	19:50	LGB Cooler Leakage
Chandrapur	Unit 3	210	6-Aug-11	11:36	9-Aug-11	01:13	Tripped on furnace pressure high.
CPP	JSW (J) U1	300	7-Aug-11	21:36	8-Aug-11	02:11	Turbine Vibration High.
Cent_Sect	KARPR2	220	7-Aug-11	09:55	10-Aug-11	18:14	Reactor tripped.
Bhusawal	Unit 2	210	8-Aug-11	06:18	8-Aug-11	08:18	Tripped.
Bhusawal	Unit 3	210	8-Aug-11	14:00	11-Aug-11	19:54	Boiler Tube Leakage.
REL	2	250	8-Aug-11	15:44	8-Aug-11	17:53	Station T/F trip.
Chandrapur	Unit 5	500	8-Aug-11	09:59	8-Aug-11	15:42	Stator Earth Fault.
Dabhol	1B	230	8-Aug-11	23:58	9-Aug-11	07:04	Gas Valve Problem.
Dabhol	1X	290	8-Aug-11	23:58	9-Aug-11	09:28	Gas Valve Problem.
CPP	JSW (J) U3	300	8-Aug-11	09:53	8-Aug-11	15:30	Generator Prot.Operated.
CPP	JSW (J) U1	300	8-Aug-11	10:30		Continued.	Bearing Vibration High.
Cent_Sect	NTPC(V-2)	210	9-Aug-11	00:18		Continued.	Wet Coal.
Cent_Sect	NTPC(V-4)	210	9-Aug-11	00:07	11-Aug-11	16:00	Flame Failure.
Koradi	Unit 7	210	9-Aug-11	07:43	9-Aug-11	10:09	Flame Failure.
Koradi	Unit 7	210	9-Aug-11	10:13	9-Aug-11	11:07	Aux.T/F problem.
Cent_Sect	NTPC(V-5)	210	9-Aug-11	17:45		Continued.	Wet coal problem.
Cent_Sect	NTPC(V-8)	500	9-Aug-11	22:47		Continued.	Wet Coal.
Cent_Sect	NTPC(K-4)	500	9-Aug-11	23:54	12-Aug-11	17:10	BLR T/L.
CPP	WPCL U-1	135	10-Aug-11	23:00	13-Aug-11	01:38	ID fan vibration problem.
Koyna	Unit 8	80	11-Aug-11	07:05	12-Aug-11	18:20	Preventive maintenance work.
Tata	Trombay 7A	120	12-Aug-11	13:09	12-Aug-11	13:58	Aux.Supply Tripped.
Tata	Trombay 7B	60	12-Aug-11	13:09	12-Aug-11	19:04	Aux.Supply Tripped.
Koyna	Unit 3	75	12-Aug-11	12:52	12-Aug-11	18:50	PVC Pressure High.
Koradi	Unit 6	210	12-Aug-11	10:33	12-Aug-11	11:46	Furnace Pressure High.
Cent_Sect	NTPC(K-6)	500	12-Aug-11	06:26	13-Aug-11	22:45	Boiler Tube Leakage.
Dabhol	2A	230	13-Aug-11	10:07	13-Aug-11	12:02	Station supply problem
Parli	Unit 5	210	13-Aug-11	01:55	13-Aug-11	06:15	Drum Level Low.
Koyna	Unit 2	75	13-Aug-11	00:10	13-Aug-11	18:30	Preventive Maintenance Work.
Dabhol	1X	290	13-Aug-11	10:07	13-Aug-11	16:01	Station supply problem
Dabhol	1B	230	13-Aug-11	10:07	13-Aug-11	13:38	Aux.Supply Fail
Dabhol	2A	230	13-Aug-11	13:13	13-Aug-11	16:48	Tripped due to DLN
Parli	Unit 5	210	13-Aug-11	09:15	13-Aug-11	14:58	Electrical Jerk
Parli	Unit 5	210	13-Aug-11	16:15		Continued.	Boiler Tube Leakage
Cent_Sect	NTPC(V-3)	210	13-Aug-11	21:29		Continued.	Wait Coal
CPP	WPCL U-3	135	13-Aug-11	12:00	14-Aug-11	19:26	Withdrawn
Parli	Unit 7	250	14-Aug-11	10:17	14-Aug-11	13:05	Furnace Pressure High.
Khaparkheda	Unit 4	210	14-Aug-11	19:04		Continued.	Furnace Pressure High.