

GENERATING UNIT OUTAGES FOR THE PERIOD

FROM 11-Oct-10 TO 17-Oct-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Koyna	ST-IV 1	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST-IV 2	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 3	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koyna	ST - IV 4	250	16-Jul-10	00.00		Continued.	Preparing Work for 2nd Lake Tapping.
Koradi	Unit 4	105	24-Aug-10	06.02		Continued.	Annual Overhaul.
Nasik	Unit 4	210	15-Sep-10	10.55		Continued.	Annual Overhaul.
Cent_Sect	NTPC(V-6)	210	19-Sep-10	13.56	11-Oct-10	05.00	Annual overhaul.
Cent_Sect	TARAPUR-3	540	3-Oct-10	22.03	11-Oct-10	02.27	Steam line work.
Cent_Sect	Tarapur 1	80	10-Oct-10	21.30		Continued.	Fuel refuelling.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Parli	Unit 4	210	9-Oct-10	11.08	11-Oct-10	11.10	BLR T/L.
Dabhol	1B	230	10-Oct-10	00.29	11-Oct-10	11.59	Flue gas leakage in turbine compartment.
Bhusawal	Unit 2	210	10-Oct-10	05.20	13-Oct-10	21.20	BLR T/L.
Uran	Unit 8	108	10-Oct-10	20.05	11-Oct-10	05.40	C.T.O.high
Bhusawal	Unit 1	58	10-Oct-10	18.10	11-Oct-10	01.40	T/L.

Chandrapur	Unit 4	210	12-Oct-10	20.19	13-Oct-10	06.05	Axial shift high
Dabhol	1B	230	11-Oct-10	20.12	13-Oct-10	01.09	High exhaust spread.
Khaparkheda	Unit 2	210	11-Oct-10	07.02	12-Oct-10	16.51	Boiler Tube Leakage.
CPP	JSW_JAIGAD	300	12-Oct-10	15.23	12-Oct-10	21.30	Tripped
Nasik	Unit 2	120	11-Oct-10	21.40	14-Oct-10	04.35	Boiler Tube Leakage.
Chandrapur	Unit 6	500	13-Oct-10	21.11	14-Oct-10	04.39	Condensor Vaccume very Low
Koradi	Unit 7	210	13-Oct-10	10.32	14-Oct-10	12.36	Air Heater problem
Khaparkheda	Unit 2	210	14-Oct-10	08.44	17-Oct-10	14.34	Boiler Tube Leakage.
REL	2	250	14-Oct-10	11.52	16-Oct-10	13.42	Boiler Tube Leakage.
Dabhol	2X	290	14-Oct-10	09.34	14-Oct-10	16.35	Emergency Trip Ckt Problem.
Dabhol	2B	230	14-Oct-10	09.37	14-Oct-10	14.47	Trip.
Uran	Unit 7	108	15-Oct-10	00.10	15-Oct-10	20.20	Filter Changing.
Parli	Unit 3	210	16-Oct-10	00.14	16-Oct-10	16.04	STN T/F I and II Trip.
Parli	Unit 4	210	16-Oct-10	00.32	16-Oct-10	10.02	STN.T/F I and II Trip.
Parli	Unit 5	210	16-Oct-10	00.08		Continued.	STN.T/F I and II Trip.
Parli	Unit 2	30	16-Oct-10	02.14	16-Oct-10	20.38	Trip.
Chandrapur	Unit 2	210	16-Oct-10	23.53	17-Oct-10	03.48	High furnace pressure.
Khaparkheda	Unit 4	210	17-Oct-10	01.01		Continued.	Boiler tube leakage.
Nasik	Unit 2	120	17-Oct-10	02.50		Continued.	Boiler tube leakage.
Uran	Unit 6	108	17-Oct-10	07.28	17-Oct-10	11.39	Bearing Vibration.
Chandrapur	Unit 7	500	17-Oct-10	07.09		Continued.	Master fuel trip.
Chandrapur	Unit 2	210	17-Oct-10	22.04		Continued.	Furnace Pressure High.