

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 10-Oct-11 TO 16-Oct-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Chandrapur	Unit 4	210	16-Aug-11	00.04	12-Oct-11	09.20	Annual Overhaul.
Bhusawal	Unit 2	210	22-Aug-11	13:13	17-Oct-11	01.30	Annual overhaul.
Parli	Unit 4	210	31-Aug-11	01.07	17-Oct-11	01.08	Annual Overhaul.
Dabhol	1B	230	5-Sep-11	23.57		Continued.	Generator Inspection
Cent_Sect	NTPC(K-4)	500	8-Sep-11	14.26		Continued.	Annual Overhaul
Parli	Unit 7	250	24-Sep-11	18.53		Continued.	Main steam temp.low.
Bhusawal	Unit 4	500	6-Oct-11	11.54	12-Oct-11	15.25	Outage.
Koradi	Unit 7	210	8-Oct-11	23.43		Continued.	Annual overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	NTPC(K-7)	500	14-Sep-11	21.37	11-Oct-11	04.35	GT Inspection work
Cent_Sect	NTPC (V-1)	210	24-Sep-11	15.16	13-Oct-11	10:59	Coal bunkering problem.
Cent_Sect	NTPC(V-3)	210	24-Sep-11	16.45	13-Oct-11	14:08	Coal bunkering problem.
Cent_Sect	Sipat-4	500	3-Oct-11	20.44	12-Oct-11	15.45	Boiler Tube Leakage.
Paras	Unit 4	250	6-Oct-11	18.47	10-Oct-11	21.00	Bunkering problem.
Koyna	ST-IV 2	250	6-Oct-11	21.30	16-Oct-11	19.30	Servo motor problem.
Nasik	Unit 3	210	7-Oct-11	22.42	10-Oct-11	00.30	Steem leakage.
Koradi	Unit 6	210	8-Oct-11	08.52	12-Oct-11	13.10	ID fan problem.
Koyna	Unit 12	80	10-Oct-11	05.08	10-Oct-11	17.30	B phase Conductor snapped of Pedambe-Karad line
Cent_Sect	NTPC(V-10)	500	10-Oct-11	11.06	11-Oct-11	15.38	Boiler Tube Leakage
Koyna	Unit 11	80	10-Oct-11	05.08	10-Oct-11	11.40	B phase Conductor snapped of Pedambe-Karad line
CPP	JSW (J) U3	300	10-Oct-11	06.25		Continued.	Colling water pump problem
Khaparkheda	Unit 5	500	10-Oct-11	09.25	10-Oct-11	14.18	Water Circulation Problem
Koradi	Unit 5	200	11-Oct-11	05.21	11-Oct-11	10.55	Tripped
REL	1	250	11-Oct-11	09.23	11-Oct-11	10.42	Control Insument Problem.
Cent_Sect	Tarapur 1	80	11-Oct-11	10.39	12-Oct-11	10.15	Bus Differential Operated.
CPP	WPCL U-4	135	11-Oct-11	17.43	11-Oct-11	20.15	Tripped.
Chandrapur	Unit 4	210	12-Oct-11	11.08	14-Oct-11	00:48	H P T Problem.
Koradi	Unit 5	200	12-Oct-11	15.45	12-Oct-11	17.36	Flame Failure.
Bhusawal	Unit 4	500	12-Oct-11	17.46	12-Oct-11	22:00	Tripped.
Parli	Unit 6	250	12-Oct-11	14.37	12-Oct-11	18.16	Main Stream Temp.Low.
Paras	Unit 3	250	13-Oct-11	01.06	13-Oct-11	04.58	Flame Failure.
Khaparkheda	Unit 1	210	13-Oct-11	05.21	15-Oct-11	10.13	No Coal Flow.
Chandrapur	Unit 3	210	13-Oct-11	15:25	13-Oct-11	17:16	Boiler Feed Pump.
Bhusawal	Unit 4	500	13-Oct-11	12:42	13-Oct-11	18:35	Flame Failure.
Khaparkheda	Unit 2	210	13-Oct-11	13:15	13-Oct-11	15:57	Flame Failure.
Khaparkheda	Unit 3	210	13-Oct-11	15:24	13-Oct-11	17:44	Furnace Pressure high.
Cent_Sect	TARAPUR-4	540	13-Oct-11	14:10	13-Oct-11	14:50	Turbine parameter variation.
Cent_Sect	NTPC(V-8)	500	13-Oct-11	04:45	16-Oct-11	12.53	Boiler Tube Leakage.
Bhusawal	Unit 4	500	13-Oct-11	23:33	16-Oct-11	05:00	Tripped.
CPP	WPCL U-2	135	13-Oct-11	23:19	14-Oct-11	04.46	Tripped.
Chandrapur	Unit 4	210	14-Oct-11	03:38	15-Oct-11	13.29	Turbine Expansion Problem.
Parli	Unit 5	210	14-Oct-11	17.00	14-Oct-11	19.54	Furnance pressure high.
CPP	WPCL U-4	135	14-Oct-11	09.25	14-Oct-11	10.26	For governer checking.
Bhusawal	Unit 3	210	15-Oct-11	06.48	15-Oct-11	11.34	A.C.failure trip.
Khaparkheda	Unit 4	210	15-Oct-11	12.53	16-Oct-11	06.50	Drum level low.
Khaparkheda	Unit 5	500	15-Oct-11	10.33	15-Oct-11	13.40	Tripped on flame failure.
Paras	Unit 4	250	15-Oct-11	10.05	16-Oct-11	16.00	CHP reversible shuttle replacement work.
CPP	WPCL U-4	135	15-Oct-11	08.36	15-Oct-11	18.56	Bearing vibration problem.
Dabhol	3A	230	15-Oct-11	18.43	15-Oct-11	21.58	Fuel gas temp. problem.
Koyna	ST - IV 4	250	15-Oct-11	14.22	16-Oct-11	05.07	Governer safety valve problem.
REL	1	250	15-Oct-11	23.59	16-Oct-11	02.29	Tripped.
Cent_Sect	NTPC(V-4)	210	15-Oct-11	13.10		Continued.	G.T.Fire
CPP	WPCL U-3	135	16-Oct-11	03.02	16-Oct-11	06:55	Due to tripping of Wardha-Warora-II.
CPP	WPCL U-4	135	16-Oct-11	03.02	16-Oct-11	11:25	Due to tripping of Wardha-Warora-II.
Bhusawal	Unit 4	500	16-Oct-11	14:00	16-Oct-11	16.42	Tripped.
CPP	WPCL U-3	135	16-Oct-11	07:55	16-Oct-11	10:24	Furnace pressure high.
Bhusawal	Unit 4	500	17-Oct-11	03.55		Continued.	Hand Tripped