

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 7-Nov-11 TO 13-Nov-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Koradi	Unit 7	210	8-Oct-11	23.43	11-Nov-11	06.58	Annual overhaul.
Koyna	ST - IV 4	250	3-Nov-11	04.42		Continued.	Attending Oil Leakage through Spherical Valve
Dabhol	2A	230	5-Nov-11	15.48		Continued.	Overhauling work
Chandrapur	Unit 2	210	5-Nov-11	11.02		Continued.	Boiler Tube Leakage,converted to AOH.
Cent_Sect	TARAPUR-4	540	6-Nov-11	01.00		Continued.	Annual Overhaul

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 4	500	17-Oct-11	03.55		Continued.	Hand Tripped
Khaparkheda	Unit 5	500	21-Oct-11	00.40	7-Nov-11	10:21	Furnace pressure low.
CPP	WPCL U-4	135	2-Nov-11	04.40		Continued.	ID Fan Problem, Preparation for P.G. Test.
Parli	Unit 3	210	4-Nov-11	15.42	8-Nov-11	14.35	Air heater problem.
Nasik	Unit 4	210	5-Nov-11	20.25	8-Nov-11	10.30	Boiler Tube Leakage
Khaparkheda	Unit 5	500	7-Nov-11	10:50	7-Nov-11	13:36	Drum level high.
Khaparkheda	Unit 3	210	7-Nov-11	16:41	7-Nov-11	21:42	Tripped on Flame Failure.
Chandrapur	Unit 5	500	8-Nov-11	06:21	12-Nov-11	16.48	Boiler Tube Leakage
Parli	Unit 3	210	8-Nov-11	14.55	8-Nov-11	18.17	Tripped changeover Supply
Chandrapur	Unit 3	210	8-Nov-11	19.02	8-Nov-11	22.40	PA Fan Tripped
CPP	WPCL U-3	135	9-Nov-11	00.01	10-Nov-11	01.29	Bottom Ash Problem
Koyna	Unit 1	75	9-Nov-11	05.50	12-Nov-11	19.05	Turbine Problem.
Parli	Unit 7	250	9-Nov-11	18.10	10-Nov-11	13.23	Air Heater Rotor Blocked.
Khaparkheda	Unit 2	210	10-Nov-11	00.30	10-Nov-11	05.41	Flame Failure.
CPP	WPCL U-2	135	10-Nov-11	01.39	14-Nov-11	04.02	For Maintenance Work.
Uran	Unit 7	108	10-Nov-11	08.09	10-Nov-11	19.32	Maintenance Work.
Khaparkheda	Unit 4	210	10-Nov-11	10.37	10-Nov-11	15.00	Flame Failure.
Khaparkheda	Unit 5	500	10-Nov-11	12.34	11-Nov-11	20.19	Drum Level High.
CPP	JSW (J) U4	300	10-Nov-11	19.07	11-Nov-11	02.04	Generator Protection.
Nasik	Unit 5	210	10-Nov-11	11.50	11-Nov-11	01.30	Air Heater Problem.
Nasik	Unit 5	210	11-Nov-11	01.50	11-Nov-11	06.50	R F A Bus Tripped.
Nasik	Unit 5	210	11-Nov-11	10.10	13-Nov-11	12.00	PA.Motor problem.
Khaparkheda	Unit 2	210	12-Nov-11	10.08	12-Nov-11	12.53	Flame failure.
CPP	JSW (J) U3	300	12-Nov-11	11.45		Continued.	Condenser cooling water leakage.
Parli	Unit 3	210	12-Nov-11	21.25		Continued.	No coal.
Chandrapur	Unit 5	500	12-Nov-11	18.36	12-Nov-11	20.44	Bay C.B.problem.
Uran	Unit 5	108	14-Nov-11	00.05		Continued.	Air filter replacement.
CPP	JSW (J) U4	300	14-Nov-11	01.17		Continued.	Turbine governing oil line leakage.
Chandrapur	Unit 6	500	14-Nov-11	04.36		Continued.	Boiler tube leakage.