

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 6-Dec-10 to 12-Dec-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Parli	Unit 5	210	19-Nov-10	01.05		Continued.	Annual Overhaul
Cent_Sect	NTPC(V-3)	210	23-Nov-10	00.20	10-Dec-10	18.30	Annual overhaul.
Nasik	Unit 2	120	23-Nov-10	00.40		Continued.	Annual Overhaul.
REL	1	250	24-Nov-10	03.55	9-Dec-10	08:02	Annual overhaul.
Cent_Sect	NTPC(K-6)	500	2-Dec-10	7:44		Continued.	Annual Overhaul
Parli	Unit 2	30	11-Dec-10	23.51		Continued.	Annual Overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Paras	Unit 2	55	16-Nov-10	23.00		Continued.	Boiler tube validity expired.
Nasik	Unit 1	120	26-Nov-10	17.50	9-Dec-10	00.45	Governing system problem.
Cent_Sect	TARAPUR-4	540	29-Nov-10	13.35	6-Dec-10	03.00	Testing work.
Nasik	Unit 3	210	3-Dec-10	22.00	6-Dec-10	02.55	Boiler Tube Leakage.
Paras	Unit 4	250	6-Dec-10	00.25	6-Dec-10	05.05	Furnace Pressure High.
Koradi	Unit 4	105	6-Dec-10	14.34	8-Dec-10	01.19	Turbine Bearing Vibration Problem.
Koradi	Unit 5	200	6-Dec-10	16.44	9-Dec-10	19:41	BLR T/L.
Dabhol	1A	230	7-Dec-10	22.57	10-Dec-10	17.57	Filter replacement.
Koyna	Unit 7	80	7-Dec-10	18.54	14-Dec-10	19.15	Turbine Guide Bearing oil level too low.
Uran	Unit 7	108	9-Dec-10	07:25	9-Dec-10	19:49	Filter replacement.
Uran	Unit 8	108	9-Dec-10	20:27	9-Dec-10	21:32	Boiler feed pump trip.
Uran	Unit B0	120	9-Dec-10	20:27	10-Dec-10	00.21	Boiler feed pump trip.
Khaparkheda	Unit 4	210	9-Dec-10	17:34	9-Dec-10	20:54	Coal gen. temp. high.
Cent_Sect	NTPC(K-4)	500	9-Dec-10	08.12	10-Dec-10	15.30	Boiler Tube Leakage.
Nasik	Unit 5	210	10-Dec-10	00.08	13-Dec-10	07.50	Boiler Tube Leakage.
Koradi	Unit 3	105	10-Dec-10	01.16	12-Dec-10	09.42	ESP problem.
Parli	Unit 1	30	10-Dec-10	09.37	10-Dec-10	13.51	I D Fan Problem.
Khaparkheda	Unit 4	210	10-Dec-10	09.53	10-Dec-10	14.57	Generator Protection Operated.
Khaparkheda	Unit 4	210	10-Dec-10	15.42	10-Dec-10	17.26	Bearing Temp. High.
Parli	Unit 1	30	10-Dec-10	14.23	10-Dec-10	21.38	Scada Testing.
REL	1	250	10-Dec-10	16.00	10-Dec-10	18.20	Speed Governing Problem.
Cent_Sect	NTPC (K-2)	210	11-Dec-10	05.31	11-Dec-10	11.21	Drum Level Low.
Khaparkheda	Unit 2	210	11-Dec-10	11.22	12-Dec-10	20.38	Boiler Tube Leakage.
Koradi	Unit 4	105	12-Dec-10	22.20		Continued.	Bearing Vibration.