

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 14-Feb-11 TO 20-Feb-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Koradi	Unit 6	210	26-Dec-10	09.23	7-Feb-11	22.15	Annual Overhaul.
Koyna	Unit 11	80	13-Jan-11	07.45	10-Feb-11	11.45	Retrofitting work of excitation system.
Khaparkheda	Unit 4	210	3-Jan-11	15.26		Continued.	Capital Overhaul.
Dabhol	3B	230	4-Jan-11	16.44		Continued.	Rehabilitation work.
Dabhol	3A	230	29-Jan-11	17.35		Continued.	Heavy leakage in CW Duct
Dabhol	3X	290	29-Jan-11	17.35		Continued.	Hand Tripped
Uran	Unit 6	108	5-Feb-11	11.28		Continued.	Stator Earth Fault

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Parli	Unit 5	210	3-Feb-11	22.00	7-Feb-11	09.01	BLR T/L.
Nasik	Unit 5	210	6-Feb-11	10.10	7-Feb-11	05.50	Heavy steam leakage at PRDS Intake Drain line
Nasik	Unit 2	120	7-Feb-11	01.05	7-Feb-11	02.05	Low Vacuum
Chandrapur	Unit 3	210	6-Feb-11	23.51	7-Feb-11	03.25	Low Drum Level
Dabhol	1A	230	7-Feb-11	22.40	8-Feb-11	13.15	Trip on Electrical Fault.
Dabhol	1B	230	7-Feb-11	22.40	8-Feb-11	07.58	Trip on Electrical Fault.
Dabhol	1X	290	7-Feb-11	22.40	8-Feb-11	10.20	Trip on Electrical Fault.
Dabhol	1A	230	8-Feb-11	13.43	8-Feb-11	15.21	Valve Separation Problem.
Koradi	Unit 6	210	8-Feb-11	06.45	8-Feb-11	12.03	Buchilz Problem.
Bhusawal	Unit 2	210	8-Feb-11	17.35	9-Feb-11	02.15	C.T.Burst.
Bhusawal	Unit 3	210	8-Feb-11	17.35	9-Feb-11	05.04	C.T.Burst.
Parli	Unit 4	210	8-Feb-11	21.21	9-Feb-11	04.35	Turbine Problem.
Koyna	Unit 1	75	9-Feb-11	16.00	9-Feb-11	17.45	Turbine Trip.
Koyna	Unit 2	75	9-Feb-11	16.00	9-Feb-11	17.45	Turbine Trip.
Koyna	Unit 5	80	9-Feb-11	16.00	9-Feb-11	17.45	Turbine Trip.
Cent_Sect	KARPR1	220	6-Feb-11	00.08	10-Feb-11	12.28	Moderator pump tripped
Uran	Unit 5	108	10-Feb-11	11.55	10-Feb-11	12.55	Boiler discrepancy.
Uran	Unit A0	120	10-Feb-11	11.55	10-Feb-11	16.53	Boiler discrepancy.
Parli	Unit 5	210	10-Feb-11	13.08	10-Feb-11	17.10	C.T.leakage.
Uran	Unit 5	108	11-Feb-11	03.45	11-Feb-11	04.43	Damper discrepancy.
Uran	Unit A0	120	11-Feb-11	03.45	11-Feb-11	16.10	Condenser pump problem.
Bhusawal	Unit 2	210	11-Feb-11	18.22	11-Feb-11	20.04	Low drum level.
Khaparkheda	Unit 2	210	11-Feb-11	12.11	12-Feb-11	20:28	BLR T/L.
Koyna	UNIT 6	75	12-Feb-11	10:40	12-Feb-11	20:36	Preventive maintenance work.
Koyna	Unit 7	80	12-Feb-11	00.20	12-Feb-11	05:40	Water Cooler Problem.
Cent_Sect	NTPC(V-10)	500	13-Feb-11	15.52	13-Feb-11	18.45	Bus Fault
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Bhusawal	Unit 3	210	10-Feb-11	18.30		Continued.	Feeder gear control problem.
Koradi	Unit 7	210	11-Feb-11	21.27		Continued.	Air heater furnace.
Parli	Unit 3	210	14-Feb-11	03.00		Continued.	Boiler Tube Leakage