

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 14-Mar-11 TO 20-Mar-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	Tarapur 2	80	4-Mar-11	01:25		Continued.	Refueling Work.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 5	108	11-Mar-11	01:35	16-Mar-11	18:52	Filter replacement
Dabhol	3A	230	12-Mar-11	03:10	15-Mar-11	00:45	Gas restriction.
Koradi	Unit 5	200	13-Mar-11	09:26	16-Mar-11	23:00	PA Fan Tripped
Nasik	Unit 5	210	14-Mar-11	04:25	15-Mar-11	15:50	HP Control Valve replacement
Dabhol	1B	230	15-Mar-11	02:37		Continued.	Upgradation work
Bhusawal	Unit 3	210	15-Mar-11	08:40	15-Mar-11	10:32	Low Drum Level.
Cent_Sect	NTPC(V-8)	500	15-Mar-11	08:06	16-Mar-11	13:31	Boiler Tube Leakage.
Cent_Sect	NTPC(K-5)	500	15-Mar-11	12:15	17-Mar-11	02:59	Boiler tube leakage.
Chandrapur	Unit 5	500	16-Mar-11	14:05	16-Mar-11	17:07	Flame Failure.
Bhusawal	Unit 2	210	16-Mar-11	10:22	19-Mar-11	04:14	Boiler tube leakage.
Koyna	ST-IV 2	250	16-Mar-11	22:00	17-Mar-11	04:40	Shaft Seal Leakage.
Koyna	Unit 2	75	16-Mar-11	13:15	16-Mar-11	15:20	Tech.Work.
Cent_Sect	NTPC(K-4)	500	17-Mar-11	21:00	18-Mar-11	21:54	BLR T/L.
Nasik	Unit 2	120	18-Mar-11	21:07		Continued.	BLR T/L.
Dabhol	2B	230	18-Mar-11	23:23		Continued.	For inlet air filter replacement.
Chandrapur	Unit 7	500	19-Mar-11	01:04	19-Mar-11	22:10	Low drum level.
Nasik	Unit 1	120	19-Mar-11	19:50		Continued.	BLR T/L.
Bhusawal	Unit 2	210	19-Mar-11	14:35	19-Mar-11	17:25	Tripped due to HP Heater level very low.
CPP	WPCL U-1	135	20-Mar-11	19:49		Continued.	Boiler Tube Leakage.
Cent_Sect	NTPC(V) 9	500	20-Mar-11	21:19		Continued.	Tripped.
Parli	Unit 6	250	21-Mar-11	04:33		Continued.	Furnace Pressure high.