

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 16-Apr-12 TO 22-Apr-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Chandrapur	Unit 1	210	11-Mar-12	08.48		Continued.	Annual Overhaul
Cent_Sect	NTPC(V-2)	210	1-Apr-12	00:01	20-Apr-12	21.10	AOH.
Cent_Sect	NTPC(K-6)	500	9-Apr-12	00.09		Continued.	Annual Overhaul

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Tata	Trombay 4	150	14-Feb-12	00.08		Continued.	Withdrawn/Cold Standby
Dabhol	1A	230	30-Mar-12	23.29		Continued.	Gas Shortage
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Dabhol	1B	230	31-Mar-12	19:45		Continued.	Maintenance work.
Dabhol	1X	290	31-Mar-12	19:43		Continued.	Maintenance work.
Parli	Unit 5	210	4-Apr-12	21.38	16-Apr-12	14.00	Coal shortage.
Parli	Unit 3	210	9-Apr-12	00.10		Continued.	PA Fan Tripped
Cent_Sect	Gandhar U3	144	9-Apr-12	21.03		Continued.	Less Schedule.
Bhusawal	Unit 4	500	12-Apr-12	10.34		Continued.	Class A Protection trip,low furnace pressure.
Bhusawal	Unit 2	210	12-Apr-12	22.20	16-Apr-12	09.32	Condensor T/L.
Bhusawal	Unit 3	210	15-Apr-12	02.18	18-Apr-12	12.28	ID fan problem.
Khaparkheda	Unit 2	210	15-Apr-12	01.22	17-Apr-12	07.15	Boiler tube leakage.
Khaparkheda	Unit 3	210	15-Apr-12	16:16	16-Apr-12	14.17	Boiler Tube Leakage.
Paras	Unit 3	250	15-Apr-12	16:16	18-Apr-12	05.10	Boiler Tube Liakage.
Cent_Sect	NTPC(V-7)	500	15-Apr-12	23:07	16-Apr-12	23.57	Boiler Tube Leakage.
CPP	JSW (J) U1	300	16-Apr-12	00:01		Continued.	P A Fan Problem.
Koyna	ST - IV 4	250	16-Apr-12	05:56	16-Apr-12	11:42	Turbine Guide Bearing Oil Temp. very High.
Khaparkheda	Unit 4	210	16-Apr-12	08.50	16-Apr-12	12.48	Flame Failure.
Koradi	Unit 6	210	17-Apr-12	22.18	20-Apr-12	07.21	Boiler Tube Leakage.
Bhusawal	Unit 3	210	18-Apr-12	20.28	18-Apr-12	23.09	Tripped,AC Supply Fail.
Paras	Unit 3	250	18-Apr-12	16.02	18-Apr-12	18.13	Drum level high.
Koyna	Unit 11	80	18-Apr-12	08.30	20-Apr-12	18.30	For bearing inspection.
CPP	JSW (J) U4	300	18-Apr-12	22.27	21-Apr-12	06.10	GTCB Tripped.
Cent_Sect	NTPC(K-7)	500	21-Apr-12	10:30	21-Apr-12	13:56	Loss of fuel.
Cent_Sect	NTPC(K-7)	500	21-Apr-12	16:05	21-Apr-12	17:58	P A Header pressure low.
Parli	Unit 5	210	21-Apr-12	06:40	21-Apr-12	10:30	Electrical Problem.
Khaparkheda	Unit 5	500	21-Apr-12	12:53		Continued.	Coal Shortage.
CPP	WPCL U-3	135	22-Apr-12	04.00	22-Apr-12	05.40	Flame Failure
Paras	Unit 3	250	22-Apr-12	05.29	22-Apr-12	14.22	Tripped
Paras	Unit 4	250	22-Apr-12	06.09	22-Apr-12	13.41	AC Supply Failure
REL	1	250	22-Apr-12	16.47		Continued.	Boiler Tube Leakage
Cent_Sect	NTPC(V-2)	210	22-Apr-12	10.32	22-Apr-12	10.51	Over Speed testing