

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 16-May-11 TO 22-May-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Koyna	Unit 10	80	13-May-11	00.00		Continued.	Annual Overhaul
Uran	Unit 6	108	21-May-11	23.25	22-May-11	00.10	Boiler Protection.
Uran	Unit A0	120	21-May-11	23.25	22-May-11	03.51	Tripped
Parli	Unit 3	210	21-May-11	22.21		Continued.	Turbine first up.
Nasik	Unit 2	120	22-May-11	04.25	22-May-11	19.30	Drum level control fail.
Cent_Sect	NTPC(V) 9	500	22-May-11	10.00		Continued.	Boiler tube leakage.
Koyna	ST - IV 3	250	22-May-11	14.23		Continued.	T/F D/C fault.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	1B	230	15-Mar-11	02.37	17-May-11	11.30	Upgradation Work.
Khaparkheda	Unit 3	210	25-Apr-11	02.51		Continued.	Annual overhaul.
Cent_Sect	NTPC (V-1)	210	7-May-11	00.46		Continued.	A/OH
Cent_Sect	NTPC(K-5)	500	10-May-11	00.00		Continued.	Annual Overhaul
Cent_Sect	NTPC(K-7)	500	11-May-11	01.15		Continued.	Fire in GT
CPP	JSW (J) U1	300	12-May-11	00.24		Continued.	Annual Overhaul.
Koyna	Unit 10	80	13-May-11	00.00		Continued.	Annual Overhaul
Parli	Unit 5	210	13-May-11	23.43	18-May-11	05.55	H P Heater Tube Leakage.
Parli	Unit 7	250	15-May-11	07.04	16-May-11	07.11	Due to CHP Problem.
Koyna	Unit 2	75	16-May-11	10.00	16-May-11	10.40	Pressure setup problem.
Khaparkheda	Unit 1	210	16-May-11	11.56	17-May-11	01.24	Main steam line leakage.
Nasik	Unit 2	120	16-May-11	12.05	20-May-11	05.08	Boiler Tube leakage.
CPP	JSW (J) U2	300	16-May-11	19.40	20-May-11	07.11	Tripping of new koyna Jaigad lines I and II.
Paras	Unit 4	250	17-May-11	04.50		Continued.	Performance guarantee test for 10 days .
Dabhol	1B	230	17-May-11	11.42	17-May-11	12.57	Tripped
Koyna	ST - IV 4	250	17-May-11	19.36	17-May-11	21.47	Turbine Guide Bearing Temperature High
Koyna	Unit 1	75	18-May-11	08.20	19-May-11	11.25	To attend Heavy Oil Leakage
Parli	Unit 7	250	18-May-11	10.11	20-May-11	10.22	Furnance Pressure High
Dabhol	1B	230	18-May-11	14.00	20-May-11	23.28	Gas Leakage.
Dabhol	2A	230	19-May-11	10.28	19-May-11	23.44	Heavy Leakage in Main Steam Line.
Dabhol	1A	230	20-May-11	10.00	20-May-11	10.57	Trip.
Dabhol	1X	290	20-May-11	10.00	20-May-11	12.30	High vaccum.
Dabhol	1A	230	20-May-11	13.22		Continued.	Rotor replacement.
Dabhol	1X	290	20-May-11	13.22		Continued.	Load restrictions due to 400 KV Dabhol-N.Koyna I tripped.
Dabhol	1B	230	21-May-11	02.17		Continued.	High speed.
Uran	Unit 6	108	21-May-11	02.22	21-May-11	05.30	Bearing vibration.
Uran	Unit 6	108	21-May-11	08.34	21-May-11	09.00	Protection operated.
Uran	Unit 5	108	21-May-11	23.25	22-May-11	00.23	Boiler Protection.