

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 16-Jul-12 TO 22-Jul-12

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Khaparkheda	Unit 2	210	1-Jun-12	05.45		Continued.	Capital overhaul.
Cent_Sect	NTPC(V-8)	500	23-Jun-12	23.38		Continued.	Annual Overhaul.
Hydro	GhatgharU1	125	5-Jul-12	15:30		Continued.	Annual Overhaul
Nasik	Unit 5	210	12-Jul-12	00.35		Continued.	Capital overhaul.
Koradi	Unit 6	210	12-Jul-12	23.56	18-Jul-12	06.24	Boiler Validity expired.
Parli	Unit 7	250	16-Jul-12	18.15		Continued.	Annual Overhaul(Earlier W/D for Water Crisis and Coal Shortage.Converted to AOH on 21/7/2012)
Tata	Trombay 7B	60	19-Jul-12	21.00		Continued.	Boiler Recertification & Gas Path Inspection.
Tata	Trombay 7A	120	19-Jul-12	22.30		Continued.	Boiler Recertification & Gas Path Inspection.
Cent_Sect	NTPC(V) 9	500	20-Jul-12	00.04		Continued.	Annual Overhaul.
Chandrapur	Unit 6	500	22-Jul-12	00.49		Continued.	Annual Overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Bhusawal	Unit 5	500	30-Mar-12	04.34		Continued.	Hand Tripped
Paras	Unit 3	250	13-Jun-12	17.05	16-Jul-12	01.03	Structure collapse near ESP.
Koyna	Unit 11	80	18-Jun-12	08.00		Continued.	Stator E/F.
Dabhol	3B	230	25-Jun-12	09.41		Continued.	Gas Shortage
Koyna	Unit 4	75	28-Jun-12	07.10	20-Jul-12	11.30	All Injectors Insitu Meter Filling Work.
Dabhol	1B	230	6-Jul-12	10.27	17-Jul-12	11.26	Gas Shortage.
Dabhol	2A	230	10-Jul-12	17.28		Continued.	Gas Shortage
Parli	Unit 3	210	13-Jul-12	02.54	19-Jul-12	08.15	P A Fan problem.
Uran	Unit 6	108	13-Jul-12	22.00		Continued.	Gas Shortage
Dabhol	2B	230	14-Jul-12	23.01		Continued.	Gas Shortage
Dabhol	2X	290	14-Jul-12	22.55		Continued.	Gas Shortage
CPP	JSW (J) U1	300	15-Jul-12	18.44	19-Jul-12	19.46	On cooling water problem.
Cent_Sect	Tarapur 1	80	16-Jul-12	22.15		Continued.	Refueling work.
Koradi	Unit 5	200	17-Jul-12	04.33	17-Jul-12	08:58	Furnace pressure high.
Koyna	ST-IV 2	250	17-Jul-12	05.17	17-Jul-12	07:42	Oil pressure drop.
Koradi	Unit 7	210	17-Jul-12	13:25	17-Jul-12	17:15	Furnace Pressure High.
Bhusawal	Unit 2	210	17-Jul-12	11:18	17-Jul-12	19:29	Boiler Flash Over
Koyna	Unit 8	80	18-Jul-12	09.00	18-Jul-12	16.25	Checking of CW system of Generator
Bhusawal	Unit 4	500	18-Jul-12	12.00		Continued.	Class A Protection operated
Khaparkheda	Unit 5	500	18-Jul-12	21.02		Continued.	CHP Problem
Bhusawal	Unit 2	210	19-Jul-12	05.46	19-Jul-12	08.02	Flame Failure
Dabhol	1A	230	19-Jul-12	09.01	21-Jul-12	12.30	Oil leakage in CTG.
Parli	Unit 6	250	19-Jul-12	23.42	20-Jul-12	14.10	Furnace pressure high.
Uran	Unit A0	120	20-Jul-12	23.03		Continued.	Gas shortage.
Uran	Unit 5	108	20-Jul-12	23.13		Continued.	Gas shortage.
Koyna	ST - IV 4	250	21-Jul-12	09.00	21-Jul-12	16.00	Preventive maint.work
Cent_Sect	Sipat U-1	660	22-Jul-12	02.03		Continued.	Loss of fuel.
Koyna	Unit 3	75	22-Jul-12	18.00		Continued.	Water cooler problem.
Bhusawal	Unit 2	210	22-Jul-12	19.44	23-Jul-12	00.05	Auxiliary supply failed.
CPP	JSW (J) U4	300	23-Jul-12	04.00		Continued.	Condenser tube cleaning work.