

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 17-Oct-11 TO 23-Oct-11

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Bhusawal	Unit 2	210	22-Aug-11	13:13	17-Oct-11	01:30	Annual overhaul.
Parli	Unit 4	210	31-Aug-11	01:07	17-Oct-11	01:08	Annual Overhaul.
Dabhol	1B	230	5-Sep-11	23:57	21-Oct-11	17:10	Generator Inspection
Cent_Sect	NTPC(K-4)	500	8-Sep-11	14:26		Continued.	Annual Overhaul
Parli	Unit 7	250	24-Sep-11	18:53	19-Oct-11	12:09	Main steam temp.low.
Koradi	Unit 7	210	8-Oct-11	23:43		Continued.	Annual overhaul.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
CPP	JSW (J) U3	300	10-Oct-11	06:25	17-Oct-11	15:53	Colling water pump problem
Cent_Sect	NTPC(V-4)	210	15-Oct-11	13:10	20-Oct-11	00:50	G.T.Fire
Bhusawal	Unit 4	500	17-Oct-11	03:55		Continued.	Hand Tripped
Cent_Sect	NTPC(V-5)	210	17-Oct-11	07:50	17-Oct-11	11:33	Hydrogen cooling problem
Bhusawal	Unit 2	210	17-Oct-11	13:24	19-Oct-11	03:38	Low Drum Level
Parli	Unit 3	210	17-Oct-11	10:30	17-Oct-11	12:15	Low Vaccume
CPP	WPCL U-4	135	17-Oct-11	15:15	17-Oct-11	16:14	Tripped
Koyna	Unit 9	80	18-Oct-11	12:53	18-Oct-11	15:00	Bus Fault @ Pedambe.
Koyna	Unit 11	80	18-Oct-11	12:53	18-Oct-11	15:00	Bus Fault @ Pedambe.
Parli	Unit 5	210	18-Oct-11	22:10	19-Oct-11	16:55	Air Heater Motor Replacement Work.
Uran	Unit 6	108	19-Oct-11	00:16	22-Oct-11	01:51	Suspected BTL.
Bhusawal	Unit 2	210	19-Oct-11	07:05	21-Oct-11	01:20	Tripped.
CPP	JSW (J) U4	300	19-Oct-11	10:53	19-Oct-11	12:32	Electrical Fault.
Parli	Unit 7	250	19-Oct-11	18:00	19-Oct-11	07:10	Flame Failure.
Koyna	ST-IV 1	250	20-Oct-11	00:01		Continued.	Servo Motor D C Leakage.
Khaparkheda	Unit 2	210	20-Oct-11	09:04	22-Oct-11	06:13	Boiler Tube Leakage.
Koyna	Unit 3	75	20-Oct-11	12:56	20-Oct-11	17:41	Butterfly valve closing fault.
Dabhol	3A	230	20-Oct-11	15:30	20-Oct-11	20:24	Transformer tripped on diff. protection.
Khaparkheda	Unit 5	500	21-Oct-11	00:40		Continued.	Furnace pressure low.
Bhusawal	Unit 2	210	21-Oct-11	08:10	21-Oct-11	12:32	Drum level low.
Parli	Unit 7	250	21-Oct-11	16:39	21-Oct-11	18:56	Condenser vaccum problem.
Parli	Unit 6	250	21-Oct-11	21:19		Continued.	Low bunkering problem.
Dabhol	1B	230	21-Oct-11	19:13	21-Oct-11	23:41	Combartion system fail.
Uran	Unit 5	108	22-Oct-11	03:30	22-Oct-11	15:58	BFP discharge low.
Uran	Unit A0	120	22-Oct-11	03:30	22-Oct-11	14:12	BFP discharge low.
Dabhol	2A	230	22-Oct-11	02:53	22-Oct-11	09:18	Low gas allocation.
CPP	JSW (J) U2	300	22-Oct-11	00:01	23-Oct-11	11:34	Maint.work
Dabhol	2A	230	22-Oct-11	10:28	22-Oct-11	15:27	Fuel temp. high.
Khaparkheda	Unit 2	210	22-Oct-11	10:13	22-Oct-11	11:53	Tripped.
Khaparkheda	Unit 2	210	22-Oct-11	13:24	22-Oct-11	15:16	Tripped.
Bhusawal	Unit 3	210	22-Oct-11	13:15		Continued.	Drum level, I D Fan inspection.
Koyna	Unit 1	75	22-Oct-11	17:05	22-Oct-11	18:05	Assymetrical load and due to occurrence at Karad.
Koyna	Unit 2	75	22-Oct-11	17:05	22-Oct-11	18:27	Assymetrical load and due to occurrence at Karad.
Koyna	Unit 4	75	22-Oct-11	17:05	22-Oct-11	18:45	Assymetrical load and due to occurrence at Karad.
Koyna	Unit 8	80	22-Oct-11	17:05	22-Oct-11	18:50	Assymetrical load and due to occurrence at Karad.
Dabhol	1A	230	22-Oct-11	17:56		Continued.	P.G. Test.
CPP	WPCL U-4	135	23-Oct-11	01:42		Continued.	Maintenance work.
Koyna	Unit 6	75	23-Oct-11	07:10	23-Oct-11	17:20	Preventive maintenance work.
Dabhol	3A	230	23-Oct-11	13:56	24-Oct-11	05:11	Generator Differantional Protecaton operated.