

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 13-Dec-10 TO 19-Dec-10

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Cent_Sect	KARPR1	220	1-Jul-08	00:10		Continued.	COH(En-Mass Coolant Clanel Replacement)
Parli	Unit 5	210	19-Nov-10	01.05		Continued.	Annual Overhaul
Nasik	Unit 2	120	23-Nov-10	00.40		Continued.	Annual Overhaul.
Cent_Sect	NTPC(K-6)	500	2-Dec-10	7:44		Continued.	Annual Overhaul
Parli	Unit 2	30	11-Dec-10	23.51		Continued.	Annual Overhaul.
Koyna	ST-IV 1	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.
Koyna	ST-IV 2	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.
Koyna	ST - IV 3	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.
Koyna	ST - IV 4	250	17-Dec-10	00.05		Continued.	For Inspection of 4B Junction Gates and Attending Leakages if any.
Koyna	Unit 1	75	19-Dec-10	07.05	19-Dec-10	17.05	Preventive Maint.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Uran	Unit 2	60	4-Oct-08	19.00		Continued.	Gas Restriction
Uran	Unit 4	60	1-Apr-09	00:00		Continued.	Gas Restriction
Uran	Unit 3	60	16-Jun-10	19.52		Continued.	R.M.Work.
Dabhol	2A	230	12-Jul-10	01.55		Continued.	Tripped due to Electrical Fault
Paras	Unit 2	55	16-Nov-10	23.00		Continued.	Boiler tube validity expired.
Koyna	Unit 7	80	7-Dec-10	18.54	14-Dec-10	19.15	Turbine Guide Bearing oil level too low.
Nasik	Unit 5	210	10-Dec-10	00.08	13-Dec-10	07.50	Boiler Tube Leakage.
Koradi	Unit 4	105	12-Dec-10	22.20		Continued.	Bearing Vibration.
Koradi	Unit 1	105	13-Dec-10	00.35	13-Dec-10	23.32	Suspected Burning of Instrumental Cable.
Nasik	Unit 5	210	13-Dec-10	08.50	13-Dec-10	10.50	Main Steam Temp.Low.
Parli	Unit 1	30	15-Dec-10	04.31		Continued.	W/Dn.
Bhusawal	Unit 2	210	15-Dec-10	15.02	17-Dec-10	06.40	ID fan problem.
Nasik	Unit 1	120	15-Dec-10	07.35	19-Dec-10	06.35	Boiler tube leakage.
Bhusawal	Unit 1	58	15-Dec-10	10.40		Continued.	Coal Mill problem.
Koyna	Unit 7	80	15-Dec-10	14.07	15-Dec-10	15.55	Turbine guide bearing oil level cleaning.
Paras	Unit 4	250	16-Dec-10	06.44	16-Dec-10	10.04	Furnace pressure high.
Uran	Unit 8	108	16-Dec-10	06.54	16-Dec-10	20.23	Air intake filter replacement.
Nasik	Unit 4	210	17-Dec-10	09.34	17-Dec-10	11.34	D.C. Supply Failure.
Bhusawal	Unit 2	210	17-Dec-10	14.02	18-Dec-10	08.32	Air Heater problem.
Tata	Trombay 8	250	17-Dec-10	21.35	18-Dec-10	03.04	P.A. Hydropressure Low.
Koradi	Unit 3	105	17-Dec-10	22.11		Continued.	Heavy Hydrogen leakage.
Uran	Unit 6	108	18-Dec-10	06.50	18-Dec-10	18.45	Filter Replacement Work.
Chandrapur	Unit 7	500	19-Dec-10	10.19		Continued.	Economiser Tube Leakage.